

Report No.: ENV/HCCL/AAQ/Oct/17-18/01

Date : 31/10/2017

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44

Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

AMBIENT AIR QUALITY TEST RESULTS

SL. No.	Location(s) ↓	Date of Sampling	PM 2.5 ($\mu\text{g}/\text{m}^3$)	PM 10 ($\mu\text{g}/\text{m}^3$)	NO ₂ ($\mu\text{g}/\text{m}^3$)	SO ₂ ($\mu\text{g}/\text{m}^3$)
	Limit(s) →		60 (24 Hrs. Av.)	100 (24 Hrs. Av.)	80 (24 Hrs. Av.)	80 (24 Hrs. Av.)
1.	In-front of Guest House	11.10.2017	21.9	45.2	ND	ND
2.	Near Crusher Area	11.10.2017	56.7	89.1	7.3	ND
3.	In- Front of Compressor House (Cement Mill)	12.10.2017	39.4	69.4	9.6	5.6

ND: Not Detected

Analysis Protocol: **IS 5182**

Sampled & Analysed by: ENVIROCON, Digboi



Checked By: Pankaj Baroi, **ENVIROCON**

NOTE:

1. Results reported are valid at the time of and under the prevailing conditions of measurement.
2. Results refer only to the particular parameters tested.
3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, Digboi Stores Building, New Market, Digboi – 786171, Assam.

Core Services: Environmental Monitoring & Data Generation, EIA & EMP, Environmental Audit & Allied Environmental Management jobs

Associate Services: Certification by Competent Person (CIF), NDT, Hydraulic Testing, Chartered Engineer Services etc.

Report No.: ENV/HCCL/SE/Oct/17-18/01

Date : 31/10/2017

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44


Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

STACK EMISSION TEST RESULTS

01	Stack Emission Test Ref. No.	HCCL/SE/Oct/17-18/01		
02	Date of Sampling	11.10.2017		
03	Material of Construction	M. S.		
04	Stack Attached To	B. F. of Crusher		
05	Stack Diameter (Meter)	1.0		
06	Flue Gas Temperature (°C)	32		
07	Exit Velocity of Gas (m/sec)	4.5		
08	Flow Rate (Nm ³ /hr)	12,433		
09	Type of Fuel Used	NA*		
10	Analysis Results of Flue Gas			
Sl. No.	Parameter(s)	Result(s)	Unit(s)	Limit(s)
i.	PM- Particulate Matter	27.4	mg/Nm ³	30

*NA: Not Applicable



Checked By: Pankaj Baroi, **ENVIROCON**

NOTE:

1. Results reported are valid at the time of and under the prevailing conditions of measurement.
2. Results refer only to the particular parameters tested.
3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, Digboi Stores Building, New Market, Digboi – 786171, Assam.

Core Services: Environmental Monitoring & Data Generation, EIA & EMP, Environmental Audit & Allied Environmental Management jobs
Associate Services: Certification by Competent Person (CIF), NDT, Hydraulic Testing, Chartered Engineer Services etc.

Report No.: ENV/HCCL/SE/Oct/17-18/02

Date : 31/10/2017

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44


Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

STACK EMISSION TEST RESULTS

01	Stack Emission Test Ref. No.	HCCL/SE/Oct/17-18/02		
02	Date of Sampling	11.10.2017		
03	Material of Construction	M. S.		
04	Stack Attached To	R.A.B.H.		
05	Stack Diameter (Meter)	3.0		
06	Flue Gas Temperature (°C)	176		
07	Exit Velocity of Gas (m/sec)	11.6		
08	Flow Rate (Nm ³ /hr)	1,95,938		
09	Type of Fuel Used	NA*		
10	Analysis Results of Flue Gas			
Sl. No.	Parameter(s)	Result(s)	Unit(s)	Limit(s)
i.	PM- Particulate Matter	27.6	mg/Nm ³	30

*NA: Not Applicable



Checked By: Pankaj Baroi, **ENVIROCON**

NOTE:

1. Results reported are valid at the time of and under the prevailing conditions of measurement.
2. Results refer only to the particular parameters tested.
3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, Digboi Stores Building, New Market, Digboi – 786171, Assam.

Core Services: Environmental Monitoring & Data Generation, EIA & EMP, Environmental Audit & Allied Environmental Management jobs
Associate Services: Certification by Competent Person (CIF), NDT, Hydraulic Testing, Chartered Engineer Services etc.

Report No.: ENV/HCCL/SE/Oct/17-18/03

Date : 31/10/2017

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44

Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

STACK EMISSION TEST RESULTS

01	Stack Emission Test Ref. No.	HCCL/SE/Oct/17-18/03		
02	Date of Sampling	11.10.2017		
03	Material of Construction	M. S.		
04	Stack Attached To	Coal Mill		
05	Stack Diameter (Meter)	1.2		
06	Flue Gas Temperature (°C)	58		
07	Exit Velocity of Gas (m/sec)	8.2		
08	Flow Rate (Nm ³ /hr)	30,062		
09	Type of Fuel Used	Coal		
10	Analysis Results of Flue Gas			
Sl. No.	Parameter(s)	Result(s)	Unit(s)	Limit(s)
i.	PM- Particulate Matter	28.7	mg/Nm ³	30



Checked By: Pankaj Baroi, **ENVIROCON**

NOTE:

1. Results reported are valid at the time of and under the prevailing conditions of measurement.
2. Results refer only to the particular parameters tested.
3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, Digboi Stores Building, New Market, Digboi – 786171, Assam.

Core Services: Environmental Monitoring & Data Generation, EIA & EMP, Environmental Audit & Allied Environmental Management jobs
Associate Services: Certification by Competent Person (CIF), NDT, Hydraulic Testing, Chartered Engineer Services etc.

Report No.: ENV/HCCL/SE/Oct/17-18/04

Date : 31/10/2017

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44

Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

STACK EMISSION TEST RESULTS

01	Stack Emission Test Ref. No.	HCCL/SE/Oct/17-18/04		
02	Date of Sampling	12.10.2017		
03	Material of Construction	M. S.		
04	Stack Attached To	Cooler E.S.P.		
05	Stack Diameter (Meter)	2.8		
06	Flue Gas Temperature (°C)	196		
07	Exit Velocity of Gas (m/sec)	11.9		
08	Flow Rate (Nm ³ /hr)	1,67,631		
09	Type of Fuel Used	Coal		
10	Analysis Results of Flue Gas			
Sl. No.	Parameter(s)	Result(s)	Unit(s)	Limit(s)
i.	PM- Particulate Matter	26.3	mg/Nm ³	30



Checked By: Pankaj Baroi, **ENVIROCON**

NOTE:

1. Results reported are valid at the time of and under the prevailing conditions of measurement.
2. Results refer only to the particular parameters tested.
3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, Digboi Stores Building, New Market, Digboi – 786171, Assam.

Core Services: Environmental Monitoring & Data Generation, EIA & EMP, Environmental Audit & Allied Environmental Management jobs
Associate Services: Certification by Competent Person (CIF), NDT, Hydraulic Testing, Chartered Engineer Services etc.

Report No.: ENV/HCCL/SE/Oct/17-18/05

Date : 31/10/2017

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44

Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

STACK EMISSION TEST RESULTS

01	Stack Emission Test Ref. No.	HCCL/SE/Oct/17-18/05		
02	Date of Sampling	12.10.2017		
03	Material of Construction	M. S.		
04	Stack Attached To	Cement Mill		
05	Stack Diameter (Meter)	1.2		
06	Flue Gas Temperature (°C)	59		
07	Exit Velocity of Gas (m/sec)	7.6		
08	Flow Rate (Nm ³ /hr)	27,778		
09	Type of Fuel Used	NA*		
10	Analysis Results of Flue Gas			
Sl. No.	Parameter(s)	Result(s)	Unit(s)	Limit(s)
i.	PM- Particulate Matter	28.9	mg/Nm ³	30

*NA: Not Applicable



Checked By: Pankaj Baroi, **ENVIROCON**

NOTE:

1. Results reported are valid at the time of and under the prevailing conditions of measurement.
2. Results refer only to the particular parameters tested.
3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, Digboi Stores Building, New Market, Digboi – 786171, Assam.

Core Services: Environmental Monitoring & Data Generation, EIA & EMP, Environmental Audit & Allied Environmental Management jobs
Associate Services: Certification by Competent Person (CIF), NDT, Hydraulic Testing, Chartered Engineer Services etc.

Report No.: ENV/HCCL/SE/Oct/17-18/06

Date : 31/10/2017

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44


Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

STACK EMISSION TEST RESULTS

01	Stack Emission Test Ref. No.	HCCL/SE/Oct/17-18/06		
02	Date of Sampling	12.10.2017		
03	Material of Construction	M. S.		
04	Stack Attached To	Packing House		
05	Stack Diameter (Meter)	0.8		
06	Flue Gas Temperature (°C)	36		
07	Exit Velocity of Gas (m/sec)	8.1		
08	Flow Rate (Nm ³ /hr)	14,137		
09	Type of Fuel Used	NA*		
10	Analysis Results of Flue Gas			
Sl. No.	Parameter(s)	Result(s)	Unit(s)	Limit(s)
i.	PM- Particulate Matter	29.3	mg/Nm ³	30

*NA: Not Applicable



Checked By: Pankaj Baroi, **ENVIROCON**

NOTE:

1. Results reported are valid at the time of and under the prevailing conditions of measurement.
2. Results refer only to the particular parameters tested.
3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, Digboi Stores Building, New Market, Digboi – 786171, Assam.

Core Services: Environmental Monitoring & Data Generation, EIA & EMP, Environmental Audit & Allied Environmental Management jobs
Associate Services: Certification by Competent Person (CIF), NDT, Hydraulic Testing, Chartered Engineer Services etc.

Report No.: ENV/HCCL/NLM/Oct/17-18/01

Date : 31/10/2017

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44


Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

NOISE LEVEL MEASUREMENT RESULTS

Measurement Date: 11.10.2017

Sl. No.	Locations	Day Time				Night Time			
		Max. (dB-A)	Min. (dB-A)	L _{eq} (dB-A)	Limit (dB-A)	Max. (dB-A)	Min. (dB-A)	L _{eq} (dB-A)	Limit (dB-A)
1	Near Kiln Area	73	70	72	75	65	61	64	70
2	Near CCR Building	65	58	63	75	54	48	52	70
3	Main Gate	61	56	59	75	49	37	46	70
4	Near Main Building	63	56	59	75	46	37	42	70

Pankaj Baroi


Checked By: Pankaj Baroi, ENVIROCON

NOTE:

1. Results reported are valid at the time of and under the prevailing conditions of measurement.
2. Results refer only to the particular parameters tested.
3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, Digboi Stores Building, New Market, Digboi – 786171, Assam.

Core Services: Environmental Monitoring & Data Generation, EIA & EMP, Environmental Audit & Allied Environmental Management jobs

Associate Services: Certification by Competent Person (CIF), NDT, Hydraulic Testing, Chartered Engineer Services etc.