



HCCL/MSPCB/23-24/013

Date: .1.1.10 2023

To.

The Member Secretary,
Meghalaya State Pollution Control Board
ARDEN Lumpyngngad
Shillong (Meghalaya) -793014

Subject: Reports on Ambient Air Quality test, Stack Emission test, Waste Water

Analysis (STP) & Noise Level Measurement Test for the month of September, 2023

Dear Sir,

Please find enclosed herewith to this letter the reports for the month of **September**, **2023** for the following test results:

Sl No.	Test Results	Purpose
1	Ambient Air Quality	
2	Stack Emission	R.A.B.H
3	Stack Emission	Coal Mill
4	Stack Emission	Cooler E.S.P
5	Waste Water Analysis Result	STP Water Analysis
6	Noise Level Measurement Test	

Thanking you,

For Hills Cement Company Ltd

HILLS CEMENT COMPANY LTD.

Tejash Bard

Authorised Signatory natory

Copy To: - (1) The Joint Director (S), Ministry of Environment, Forest & Climate

Change

NE Regional Office, Lumbatngen, Shillong 793021 for information

(2) The Regional Director Regional Directorate (NE), Central Pollution Control Board, TUM-SIR, Lower Motinagar, Near Fire Brigrade HQ, Shillong-793014





HCCL/MSPCB/23-24/014

Date: 10 2023

To,
The Member Secretary,
Meghalaya State Pollution Control Board
ARDEN Lumpyngngad
Shillong (Meghalaya) -793014

Subject: Reports on Ambient Air Quality test, Stack Emission test, Waste Water
Analysis (STP) & Noise Level Measurement Test for the month of September, 2023

Dear Sir,

Please find enclosed herewith to this letter the reports for the month of **September**, 2023 for the following test results:

Sl No.	Test Results	Purpose
1	Ambient Air Quality	-
2	Stack Emission R.A.B.H	
3	Stack Emission	Coal Mill
4	Stack Emission	Cooler E.S.P
5	Waste Water Analysis Result	STP Water Analysis
6	Noise Level Measurement Test	

Thanking you,

भारत संस्कार / GOVT OF INDIA

For Hills Cement Company Ltd

HILLS CEMENT COMPANY LTD.

Tyash Bad

Authorised Signatory

Copy To: - (1) The Joint Director (S), Ministry of Environment, Forest & Climate Change

NE Regional Office, Lumbatngen, Shillong 793021 for information

(2) The Regional Director Regional Directorate (NE), Central Pollution Control Board, TUM-SIR, Lower Motinagar, Near Fire Brigrade HQ, Shillong-793014

HILLS CEMENT COMPANY LIMITED

CORPORATE OFFICE "SHIVAM COMPLEX", Bharalumukh, A.T. Road, Guwahati, Assam, PIN-781009 | Ph.: (0361) 2735527/52 | E: hr@hccl.in | info@hccl.in | REGISTERED OFFICE & WORKS: Village Mynkree, 116KM Stone (NH44), Sub Div: Khliehriat, Dist: Jaintia Hills, Meghalaya, Pin-793200





HCCL/MSPCB/23-24/015

Date: ... 10 2023

To,
The Member Secretary,
Meghalaya State Pollution Control Board
ARDEN Lumpyngngad
Shillong (Meghalaya) -793014

Subject: Reports on Ambient Air Quality test, Stack Emission test, Waste Water
Analysis (STP) & Noise Level Measurement Test for the month of September, 2023

Dear Sir,

Please find enclosed herewith to this letter the reports for the month of **September**, 2023 for the following test results:

SI No.	Test Results	Purpose '
1	Ambient Air Quality	-
2	Stack Emission	R.A.B.H
3	Stack Emission	Coal Mill
4	Stack Emission	Cooler E.S.P
5	Waste Water Analysis Result	STP Water Analysis
6	Noise Level Measurement Test	

Thanking you,

For Hills Cement Company Ltd

HILLS CEMENT COMPANY LTD.

Tyjash Band Authorised Signatory matory

Copy To: - (1) The Joint Director (S), Ministry of Environment, Forest & Climate Change

NE Regional Office, Lumbatngen, Shillong 793021 for information

(2) The Regional Director Regional Directorate (NE), Central Pollution Control Board, TUM-SIR, Lower Motinagar, Near Fire Brigrade HQ,

Shillong-793014

Email No: 20 shillong. cpcb@nic. in



ISO 9001:2015 Certified ISO 45001:2018 Certified

E-mail: envirocon@rediffmail.com

Report No.: ENV/HCCL/23-24/AA-09/01 Order No.: HCCL/HO/ENV/21-22/01

Date : 05/10/2023 Date : 08/04/2021

Report Issued To: HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44, Sub Division: Khliehriat, Dist.: Jaintia Hills, Meghalaya

AMBIENT AIR QUALITY TEST RESULTS

Sl. No.	LOCATION(S) ↓	Date of Sampling	PM 2.5 (μg/m³)	PM 10 (μg/m³)	SO ₂ (μg/m³)	NO ₂ (μg/m³)
	LIMIT(S) →		60	100	80	80
01	In-front of Guest House	16.09.2023	25.9	50.8	<5.0	<6.0
02	Near Crusher Area	16.09.2023	30.2	52.6	7.7	8.4
03	In- Front of Compressor House (Cement Mill)	17.09.2023	33.7	53.9	7.2	7.6
04	Near Mines	17.09.2023	31.6	49.7	<5.0	<6.0

Analysis Protocol: IS 5182



Checked By: Mr. Pankaj Baroi, ENVIROCON

- 2. Results refer only to the particular parameters tested.
- 3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, I.O.C.L (AOD) New Market, Digboi 786171, Assam.



ISO 9001:2015 Certified ISO 45001:2018 Certified

E-mail: envirocon@rediffmail.com

Report No.: ENV/HCCL/23-24/N-09/01 Order No.: HCCL/HO/ENV/21-22/01

Date : 05/10/2023 Date : 08/04/2021

Report Issued To: HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44, Sub Division: Khliehriat, Dist.: Jaintia Hills, Meghalaya

NOISE LEVEL MEASUREMENT RESULTS

Sl. No. Location(s)		Date	Day Time		Night Time	
	Of Measurement	L _{eq} (dB-A)	Limit (dB-A)	L _{eq} (dB-A)	Limit (dB-A)	
1	In-front of Guest House	16.09.2023	53.4	75	46.9	70
2	Near Crusher Area	16.09.2023	69.6	75	64.7	70
3	In- Front of Compressor House (Cement Mill)	17.09.2023	70.5	75	65.3	70
4	Near Mines	17.09.2023	52.4	75	49.3	70



Checked By: Mr. Pankaj Baroi, ENVIROCON

NOTE: 1. Results reported are valid at the time of and under the prevailing conditions of measurement.

- 2. Results refer only to the particular parameters tested.
- 3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, I.O.C.L (AOD) New Market, Digboi 786171, Assam.

Core Services: Environmental Monitoring & Data Generation, EIA & EMP, Environmental Audit & Allied Environmental Management jobs

Associate Services: Certification by Competent Person (CIF), NDT, Hydraulic Testing, Chartered Engineer Services etc.

E-mail: envirocon@rediffmail.com

ISO 9001:2015 Certified ISO 45001:2018 Certified

Report No.: ENV/HCCL/23-24/SE-09/01 Order No.: HCCL/HO/ENV/21-22/01

Date : 05/10/2023 Date : 08/04/2021

Report Issued To: HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44, Sub Division: Khliehriat, Dist.: Jaintia Hills, Meghalaya

STACK EMISSION TEST RESULTS

01	Test Ref. No.	HCCL/2023/SE-09/01			
02	Date of Sampling		16.09.2023		
03	Material of Construction		M. S.		
04	Stack Attached To		R.A.B.H.		
05	Stack Diameter (Meter)		3.0		
06	Flue Gas Temperature (°C)	179			
07	Exit Velocity of Gas (m/sec)	21.4			
08	Flow Rate (Nm³/hr)	359073			
09	Type of Fuel Used	NA*			
	Analysis Resul	lts of Flue Gas			
Sl. No.	Parameter(s)	Result(s) Unit(s) Limit(s)			
i.	Particulate Matter	26 mg/Nm³ 30			
ii.	Sulphur Dioxide (as SO ₂)	702 mg/Nm ³ 1000			
iii.	Oxides of Nitrogen (as NO _x)	378	mg/Nm³	800	

^{*}NA: Not Applicable



Checked By: Mr. Pankaj Baroi, ENVIROCON

- 2. Results refer only to the particular parameters tested.
- $3.\ This test report shall not be reproduced except in full, without the written permission of ENVIROCON, I.O.C.L (AOD) New Market, Digboi 786171, Assam.$

E-mail: envirocon@rediffmail.com

ISO 9001:2015 Certified ISO 45001:2018 Certified

Report No.: ENV/HCCL/23-24/SE-09/02 Order No.: HCCL/HO/ENV/21-22/01

Date : 05/10/2023 Date : 08/04/2021

Report Issued To: HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44, Sub Division: Khliehriat, Dist.: Jaintia Hills, Meghalaya

STACK EMISSION TEST RESULTS

01	Test Ref. No.	HCCL/2023/SE-09/02		
02	Date of Sampling		16.09.2023	
03	Material of Construction		M. S.	
04	Stack Attached To		Coal Mill	
05	Stack Diameter (Meter)		1.2	
06	Flue Gas Temperature (°C)	55		
07	Exit Velocity of Gas (m/sec)	12.1		
08	Flow Rate (Nm³/hr)	44765		
09	Type of Fuel Used	Coal		
	Analysis Resul	lts of Flue Gas		
Sl. No.	Parameter(s)	Result(s)	Unit(s)	Limit(s)
i.	Particulate Matter	23 mg/Nm³ 30		
ii.	Sulphur Dioxide (as SO ₂)	632 mg/Nm ³ 1000		
iii.	Oxides of Nitrogen (as NO _x)	294	mg/Nm³	800



Checked By: Mr. Pankaj Baroi, ENVIROCON

NOTE: 1. Results reported are valid at the time of and under the prevailing conditions of measurement.

2. Results refer only to the particular parameters tested.

 $3.\ This test report shall not be reproduced except in full, without the written permission of ENVIROCON, I.O.C.L (AOD) New Market, Digboi - 786171, Assam.$

E-mail: envirocon@rediffmail.com

ISO 9001:2015 Certified ISO 45001:2018 Certified

Report No.: ENV/HCCL/23-24/SE-09/03 Order No.: HCCL/HO/ENV/21-22/01

Date : 05/10/2023 Date : 08/04/2021

Report Issued To: HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44, Sub Division: Khliehriat, Dist.: Jaintia Hills, Meghalaya

STACK EMISSION TEST RESULTS

01	Test Ref. No.	HCCL/2023/SE-09/03			
02	Date of Sampling		17.09.2023		
03	Material of Construction		M. S.		
04	Stack Attached To		Cooler E.S.P.		
05	Stack Diameter (Meter)		2.8		
06	Flue Gas Temperature (°C)	231			
07	Exit Velocity of Gas (m/sec)	12.6			
08	Flow Rate (Nm³/hr)	165166			
09	Type of Fuel Used	NA*			
	Analysis Resul	lts of Flue Gas			
Sl. No.	Parameter(s)	Result(s)	Unit(s)	Limit(s)	
i.	Particulate Matter	22 mg/Nm ³ 30			
ii.	Sulphur Dioxide (as SO ₂)	BDL# mg/Nm³ 1000			
iii.	Oxides of Nitrogen (as NO _x)	BDL#	mg/Nm³	800	

*NA: Not Applicable

#BDL: Below Detectable Limit



Checked By: Mr. Pankaj Baroi, ENVIROCON

- 2. Results refer only to the particular parameters tested.
- 3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, I.O.C.L (AOD) New Market, Digboi 786171, Assam.



E-mail: envirocon@rediffmail.com

ISO 9001:2015 Certified ISO 45001:2018 Certified

Report No.: ENV/HCCL/23-24/WW-09/01 Order No.: HCCL/HO/ENV/21-22/01

Date : 05/10/2023 Date : 08/04/2021

Report Issued To: HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44, Sub Division: Khliehriat, Dist.: Jaintia Hills, Meghalaya

WASTE WATER ANALYSIS RESULTS

Sample Ref. No. : HCCL/2023/WW-2509/01

Sample Type/Source : Waste Water (Treated)/STP Outlet Sample Collected By : Representative of ENVIROCON

Sample Collected On : 25.09.2023 Sample Received On : 27.09.2023 Analysis Protocol : IS 3025

Sl. No.	Parameter(s)	Unit(s)	Result(s)	Limit (As Per CPCB Standards)
1.	pН		6.82	5.5 – 9.0
2.	Temperature	°C	26.1	shall not exceed 5°C above the receiving water temperature
3.	Total Suspended Solids	mg/l	36	100
4.	Biochemical Oxygen Demand	mg/l	25	30
5.	Chemical Oxygen Demand	mg/l	99	250
6.	Oil & Grease	mg/l	<4.0	10
7.	Total Residual Chlorine	mg/l	<0.01	1.0
8.	Ammonical Nitrogen (as N)	mg/l	4.7	50
9.	Total Kjeldahl Nitrogen (as NH ₃)	mg/l	12.2	100
10.	Free Ammonia (as NH ₃)	mg/l	<0.01	5.0



Checked By: Mr. Pankaj Baroi, ENVIROCON

- 2. Results refer only to the particular parameters tested.
- 3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, I.O.C.L (AOD) New Market, Digboi 786171, Assam.



Envirocon Building, I.O.C.L (AOD) New Market P.O.: Digboi, Dist.: Tinsukia, Assam – 786 171 Ph: 03751-264414, 9435008657, 8876028672 E-mail: envirocon@rediffmail.com

ISO 9001:2015 Certified ISO 45001:2018 Certified

Report No.: ENV/HCCL/23-24/FE-09/01 Order No.: HCCL/HO/ENV/21-22/01

Date : 05/10/2023 Date : 08/04/2021

Report Issued To: HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44, Sub Division: Khliehriat, Dist.: Jaintia Hills, Meghalaya

PROCESS FUGITIVE EMISSION TEST RESULTS

Date	Locations	Fugitive Emission Results for SPM (µg/m³)	Limits (μg/m³)
16.09.2023	Coal Storage Section	466	2000
16.09.2023	Lime Stone Storage Section	1537	5000
17.09.2023	Fly-ash Storage Section	1951	5000
17.09.2023	Cement Packing Section	2133	5000



Checked By: Mr. Pankaj Baroi, ENVIROCON

NOTE: 1. Results reported are valid at the time of and under the prevailing conditions of measurement.

2. Results refer only to the particular parameters tested.

3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, I.O.C.L (AOD) New Market, Digboi - 786171, Assam.

E-mail: envirocon@rediffmail.com

ISO 9001:2015 Certified ISO 45001:2018 Certified

Report No.: ENV/HCCL/23-24/WW-09/02 Order No.: HCCL/HO/ENV/21-22/01

Date : 05/10/2023 Date : 08/04/2021

Report Issued To: HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44, Sub Division: Khliehriat, Dist.: Jaintia Hills, Meghalaya

WASTE WATER ANALYSIS RESULTS

Sample Ref. No. : HCCL/2023/WW-2509/01

Sample Type/Source : Waste Water (Treated)/ETP Outlet Sample Collected By : Representative of ENVIROCON

Sample Collected On : 25.09.2023 Sample Received On : 27.09.2023 Analysis Protocol : IS 3025

Sl. No.	Parameter(s)	Unit(s)	Result(s)	Limit (As Per G.S.R. 801(E), 31.12.1993)
1.	рН		6.84	5.5 - 9.0
2.	Temperature	°C	26.1	shall not exceed 5°C above the receiving water temperature
3.	Total Suspended Solids	mg/l	26	100
4.	Biochemical Oxygen Demand	mg/l	21	30
5.	Chemical Oxygen Demand	mg/l	82	250
6.	Oil & Grease	mg/l	<4.0	10
7.	Total Residual Chlorine	mg/l	< 0.01	1.0
8.	Ammonical Nitrogen (as N)	mg/l	3.4	50
9.	Total Kjeldahl Nitrogen (as NH ₃)	mg/l	8.9	100
10.	Free Ammonia (as NH ₃)	mg/l	<0.01	5.0



Checked By: Mr. Pankaj Baroi, ENVIROCON

- 2. Results refer only to the particular parameters tested.
- 3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, I.O.C.L (AOD) New Market, Digboi 786171, Assam.