

Website: www.tajcement.com CIN: U26942ML2003PLC007295

Date: 14.02.2024

HCCL/MSPCB/23-24/020

To.

The Member Secretary,

Meghalaya State Pollution Control Board,

ARDEN Lumpyngngad,

Shillong (Meghalaya) -793014

Subject: Reports on Ambient Air Quality test, Stack Emission test, Waste Water Analysis (STP) & Noise Level Measurement Test for the month of January, 2024.

Dear Sir,

Please find enclosed herewith to this letter the reports for the month of January, 2024 for the following test results:

SI No.	Test Results	Purpose
1	Ambient Air Quality	
2	Stack Emission	R.A.B.H
3	Stack Emission	Coal Mill
4	Stack Emission	Cooler E.S.P
5	Waste Water Analysis Result	STP Water Analysis
6	Noise Level Measurement Test	

Thanking you,

For Hills Cement Company Ltd

Authorised Signatory

The Joint Director (S), Ministry of Environment, Forest & Climate Change

NH Regional Office, Lumbatngen, Shillong 793021 for information

The Regional Director Regional Directorate (NE), Central Pollution

Control Board, TUM-SIR, Lower Motinagar, Near Fire Brigrade HQ, Shillong-793014



Date: 14.02.2024



HCCL/MSPCB/23-24/020

To.

The Member Secretary,

Meghalaya State Pollution Control Board,

ARDEN Lumpyngngad,

Shillong (Meghalaya) -793014

Subject: Reports on Ambient Air Quality test, Stack Emission test, Waste Water Analysis (STP) & Noise Level Measurement Test for the month of January, 2024.

Dear Sir,

Please find enclosed herewith to this letter the reports for the month of January, 2024 for the following test results:

SI No.	Test Results	Purpose	
1	Ambient Air Quality	æ	
2	Stack Emission	R.A.B.H	
3	Stack Emission	Coal Mill	
4	Stack Emission	Cooler E.S.P	
5	Waste Water Analysis Result	STP Water Analys	
6	Noise Level Measurement Test		

Thanking you,

For Hills Cement Company Ltd

Authorised Signatory

The Joint Director (S), Ministry of Environment, Forest & Climate Change

NE Regional Office, Lumbatngen, Shillong 793021 for information

(2) The Regional Director Regional Directorate (NE), Central Pollution Control Board, TUM-SIR, Lower Motinagar, Near Fire Brigrade HQ,

Shillong-793014





HCCL/MSPCB/23-24/020

To,

The Member Secretary,

Meghalaya State Pollution Control Board, ARDEN Lumpyngngad, Shillong (Meghalaya) -793014

Date: 14.02.2024

Subject: Reports on Ambient Air Quality test, Stack Emission test, Waste Water Analysis (STP) & Noise Level Measurement Test for the month of January, 2024.

Dear Sir,

Please find enclosed herewith to this letter the reports for the month of January, 2024 for the following test results:

SI No.	Test Results	Purpose
1	Ambient Air Quality	
2	Stack Emission	R.A.B.H
3	Stack Emission	Coal Mill
4	Stack Emission	Cooler E.S.P
5	Waste Water Analysis Result	STP Water Analysis
6	Noise Level Measurement Test	

Thanking you,

For Hills Cement Company Ltd

Authorised Signatory

The Joint Director (S), Ministry of Environment, Forest & Climate Change

E Regional Office, Lumbatngen, Shillong 793021 for information

(2) The Regional Director Regional Directorate (NE), Central Pollution

Control Board, TUM-SIR, Lower Motinagar, Near Fire Brigrade HQ

Shillong-793014



Envirocon Building, I.O.C.L (AOD) New Market P.O.: Digboi, Dist.: Tinsukia, Assam – 786 171 Ph: 03751-264414, 9435008657, 8876028672 E-mail: envirocon@rediffmail.com

ISO 9001:2015 Certified ISO 45001:2018 Certified

Report No.: ENV/HCCL/23-24/AA-01/01 Order No.: HCCL/HO/ENV/21-22/01

Date : 05/02/2024 Date : 08/04/2021

Report Issued To: HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44, Sub Division: Khliehriat, Dist.: Jaintia Hills, Meghalaya

AMBIENT AIR QUALITY TEST RESULTS

Sl. No.	LOCATION(S) ↓	Date of Sampling	PM 2.5 (μg/m³)	PM 10 (μg/m³)	SO ₂ (μg/m³)	NO ₂ (μg/m³)
51 1101	LIMIT(S) →		60	100	80	80
01	In-front of Guest House	16.01.2024	27.5	55.8	<5.0	<6.0
02	Near Crusher Area	16.01.2024	34.2	59.2	7.7	8.6
03	In- Front of Compressor House (Cement Mill)	17.01.2024	38.6	57.3	7.6	8.3
04	Near Mines	17.01.2024	31.3	54.9	<5.0	<6.0

Analysis Protocol: IS 5182



Checked By: Mr. Pankaj Baroi, ENVIROCON

- 2. Results refer only to the particular parameters tested.
- 3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, I.O.C.L (AOD) New Market, Digboi 786171, Assam.



ISO 9001:2015 Certified ISO 45001:2018 Certified

E-mail: envirocon@rediffmail.com

Report No.: ENV/HCCL/23-24/N-01/01 Order No.: HCCL/HO/ENV/21-22/01

Date : 05/02/2024 Date : 08/04/2021

Report Issued To: HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44, Sub Division: Khliehriat, Dist.: Jaintia Hills, Meghalaya

NOISE LEVEL MEASUREMENT RESULTS

GL V	()	Date	Day Time		Night Time	
Sl. No.	Location(s)	Of Measurement	L _{eq} (dB-A)	Limit (dB-A)	L _{eq} (dB-A)	Limit (dB-A)
1	In-front of Guest House	16.01.2024	61.3	75	56.7	70
2	Near Crusher Area	16.01.2024	71.1	75	64.6	70
3	In- Front of Compressor House (Cement Mill)	17.01.2024	70.3	75	66.8	70
4	Near Mines	17.01.2024	58.5	75	53.4	70



Checked By: Mr. Pankaj Baroi, ENVIROCON

- 2. Results refer only to the particular parameters tested.
- 3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, I.O.C.L (AOD) New Market, Digboi 786171, Assam.

E-mail: envirocon@rediffmail.com

ISO 9001:2015 Certified ISO 45001:2018 Certified

Report No.: ENV/HCCL/23-24/SE-01/03 Order No.: HCCL/HO/ENV/21-22/01

Date : 05/02/2024 Date : 08/04/2021

Report Issued To: HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44, Sub Division: Khliehriat, Dist.: Jaintia Hills, Meghalaya

STACK EMISSION TEST RESULTS

01	Test Ref. No.	HCCL/2024/SE-01/03			
02	Date of Sampling	17.01.2024			
03	Material of Construction		M. S.		
04	Stack Attached To		R.A.B.H.		
05	Stack Diameter (Meter)		3.0		
06	Flue Gas Temperature (°C)	175			
07	Exit Velocity of Gas (m/sec)	19.3			
08	Flow Rate (Nm³/hr)	326728			
09	Type of Fuel Used	NA*			
	Analysis Resul	ts of Flue Gas			
Sl. No.	Parameter(s)	Result(s) Unit(s) Limit(s)			
i.	Particulate Matter	26 mg/Nm ³ 30			
ii.	Sulphur Dioxide (as SO ₂)	728	mg/Nm³	1000	
iii.	Oxides of Nitrogen (as NO _x)	266 mg/Nm³ 800			

^{*}NA: Not Applicable



Checked By: Mr. Pankaj Baroi, ENVIROCON

- 2. Results refer only to the particular parameters tested.
- 3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, I.O.C.L (AOD) New Market, Digboi 786171, Assam.

E-mail: envirocon@rediffmail.com

ISO 9001:2015 Certified ISO 45001:2018 Certified

Report No.: ENV/HCCL/23-24/SE-01/01 Order No.: HCCL/HO/ENV/21-22/01

Date : 05/02/2024 Date : 08/04/2021

Report Issued To: HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44, Sub Division: Khliehriat, Dist.: Jaintia Hills, Meghalaya

STACK EMISSION TEST RESULTS

		_			
01	Test Ref. No.	HCCL/2024/SE-01/01			
02	Date of Sampling	16.01.2024			
03	Material of Construction		M. S.		
04	Stack Attached To		Coal Mill		
05	Stack Diameter (Meter)	1.2			
06	Flue Gas Temperature (°C)	52			
07	Exit Velocity of Gas (m/sec)	11.3			
08	Flow Rate (Nm³/hr)	42191			
09	Type of Fuel Used	Coal			
	Analysis Resul	lts of Flue Gas			
Sl. No.	Parameter(s)	Result(s) Unit(s) Limit(s)			
i.	Particulate Matter	24 mg/Nm³ 30			
ii.	Sulphur Dioxide (as SO ₂)	493 mg/Nm³ 1000			
iii.	Oxides of Nitrogen (as NO _x)	141 mg/Nm³ 800			



Checked By: Mr. Pankaj Baroi, ENVIROCON

NOTE: 1. Results reported are valid at the time of and under the prevailing conditions of measurement.

2. Results refer only to the particular parameters tested.

3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, I.O.C.L (AOD) New Market, Digboi - 786171, Assam.

E-mail: envirocon@rediffmail.com

ISO 9001:2015 Certified ISO 45001:2018 Certified

Report No.: ENV/HCCL/23-24/SE-01/02 Order No.: HCCL/HO/ENV/21-22/01

Date : 05/02/2024 Date : 08/04/2021

Report Issued To: HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44, Sub Division: Khliehriat, Dist.: Jaintia Hills, Meghalaya

STACK EMISSION TEST RESULTS

01	Test Ref. No.	HCCL/2024/SE-01/02			
02	Date of Sampling	16.01.2024			
03	Material of Construction		M. S.		
04	Stack Attached To		Cooler E.S.P.		
05	Stack Diameter (Meter)		2.8		
06	Flue Gas Temperature (°C)	227			
07	Exit Velocity of Gas (m/sec)	10.3			
08	Flow Rate (Nm³/hr)	136097			
09	Type of Fuel Used	NA*			
	Analysis Resul	ts of Flue Gas			
Sl. No.	Parameter(s)	Result(s) Unit(s) Limit(s)			
i.	Particulate Matter	27 mg/Nm ³ 30			
ii.	Sulphur Dioxide (as SO ₂)	BDL# mg/Nm³ 1000			
iii.	Oxides of Nitrogen (as NO _x)	BDL# mg/Nm³ 800			

*NA: Not Applicable

#BDL: Below Detectable Limit



Checked By: Mr. Pankaj Baroi, ENVIROCON

NOTE: 1. Results reported are valid at the time of and under the prevailing conditions of measurement.

 $2. \ Results \, refer \, only \, to \, the \, particular \, parameters \, tested.$

3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, I.O.C.L (AOD) New Market, Digboi - 786171, Assam.

E-mail: envirocon@rediffmail.com

ISO 9001:2015 Certified ISO 45001:2018 Certified

Report No.: ENV/HCCL/23-24/WW-01/01 Order No.: HCCL/HO/ENV/21-22/01

Date : 05/02/2024 Date : 08/04/2021

Report Issued To: HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44, Sub Division: Khliehriat, Dist.: Jaintia Hills, Meghalaya

WASTE WATER ANALYSIS RESULTS

Sample Ref. No. : HCCL/2024/WW-1701/01

Sample Type/Source : Waste Water (Treated)/STP Outlet Sample Collected By : Representative of ENVIROCON

Sample Collected On : 17.01.2024 Sample Received On : 20.01.2024 Analysis Protocol : IS 3025

Sl. No.	Parameter(s)	Unit(s)	Result(s)	Limit (As Per CPCB Standards)
1.	рН		7.19	5.5 - 9.0
2.	Temperature	0C	25.4	shall not exceed 5°C above the receiving water temperature
3.	Total Suspended Solids	mg/l	31	100
4.	Biochemical Oxygen Demand	mg/l	23	30
5.	Chemical Oxygen Demand	mg/l	93	250
6.	Oil & Grease	mg/l	<4.0	10
7.	Total Residual Chlorine	mg/l	<0.01	1.0
8.	Ammonical Nitrogen (as N)	mg/l	3.2	50
9.	Total Kjeldahl Nitrogen (as NH ₃)	mg/l	9.5	100
10.	Free Ammonia (as NH ₃)	mg/l	< 0.01	5.0



Checked By: Mr. Pankaj Baroi, ENVIROCON

- 2. Results refer only to the particular parameters tested.
- 3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, I.O.C.L (AOD) New Market, Digboi 786171, Assam.