

HCCL/MSPCB/19-20/01

Date: 12th Oct 2019

To,
The Member Secretary,
Meghalaya State Pollution Control Board
ARDEN Lumpyngngad
Shillong (Meghalaya) -793014

Subject: Reports on Ambient air quality test results, Stack Emission Test Results & Waste Water
Analysis for the month of Sept 2019

Dear Sir,

Please find enclosed herewith to this letter the reports for the month of **Sept 2019** for the following test results:

SI No.	Test Results	Purpose		
1	Ambient air quality	-		
2	Stack Emission	B.F of Crusher		
3	Stack Emission	R.A.B.H		
4	Stack Emission	Coal Mill		
5	Stack Emission	Cooler E.S.P		
6	Stack Emission	Cement Mill		
7	Stack Emission	Packing House		
8	Waste Water Analy Result	sis Treated ETP Water		

Thanking you,

For Hills Cement Company Ltd

HILLS CEMENT CO. LTD.

Authorised Signatory
Authorised Signatory

Copy To: - The Joint Director (S), Ministry of Environment, Forest & Climate Change NE Regional Office, Lumbatngen, Shillong 793021 for information

HILLS CEMENT COMPANY LTD.



HCCL/MSPCB/19-20/01

Date: 12th Oct 2019

To,
The Member Secretary,
Meghalaya State Pollution Control Board
ARDEN Lumpyngngad
Shillong (Meghalaya) -793014

Subject: Reports on Ambient air quality test results, Stack Emission Test Results & Waste Water Analysis for the month of Sept 2019

Dear Sir,

Please find enclosed herewith to this letter the reports for the month of **Sept 2019** for the following test results:

SI No.	Test Results	Purpose	
1	Ambient air quality		
2	Stack Emission	B.F of Crusher	
3	Stack Emission	R.A.B.H	
4	Stack Emission	Coal Mill	
5	Stack Emission	Cooler E.S.P	
6	Stack Emission	Cement Mill	
7	Stack Emission	Packing House	
8	Waste Water Analysi Result	is Trea ted ETP Water	

Thanking you,

For Hills Cement Company Ltd HILLS CEMENT CO. LTD.

Authorised Signatory
Authorised Signatory

Copy To: The Joint Director (S), Ministry of Environment, Forest & Climate Change NE Regional Office, Lumbatngen, Shillong 793021 for information

HILLS CEMENT COMPANY LTD.



Digboi Stores Building, New Market Digboi, Assam – 786 171 Ph: 03751-264414, 9435008657, 8876028672 E-mail: envirocon@rediffmail.com

Website: www.envirocon.net.in



Report No.: ENV/HCCL/AAQ/SEPT/19-20/01

:03/10/2019

W. O. No. : Nil

Date : 11/03/2019

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44 Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

Date

AMBIENT AIR QUALITY TEST RESULTS

SL.	Location(s)	Date of	PM 2.5 (μg/m³)	PM 10 (μg/m³)	NO ₂ (μg/m ³)	SO ₂ (μg/m³)	
No.	Limit(s)	Sampling	60 (24 Hrs. Av.)	100 (24 Hrs. Av.)	80 (24 Hrs. Av.)	80 (24 Hrs. Av.)	
1.	In-front of Guest House	25.09,2019	20.8	38.4	BDL	BDL	
2.	Near Crusher Area	26.09.2019	33.6	64.8	8.3	5.3	
3.	In- Front of Compressor House (Cement Mill)	26.09.2019	28.4	58.7	8.9	5.1	
4.	Near Mines	25.09.2019	38.9	75.6	5.3	BDL	

Analysis Protocol: IS 5182 BDL: Below Detectable Level



Checked By: Mr. Pankaj Baroi, ENVIROCON

NOTE: 1. Results reported are valid at the time of and under the prevailing conditions of measurement.

2. Results refer only to the particular parameters tested.



Digboi Stores Building, New Market Digboi, Assam – 786 171

Ph: 03751-264414, 9435008657, 8876028672

E-mail: envirocon@rediffmail.com Website: www.envirocon.net.in



Report No.: ENV/HCCL/SE/SEPT/19-20/01

Date : 03/10/2019

W. O. No. : Nil

Date : 11/03/2019

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44 Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

STACK EMISSION TEST RESULTS

01	Stack Emission Test Ref. No.	HC	HCCL/SE/19-20/09-01			
02	Date of Sampling		25.09.2019			
03	Material of Construction		M. S.			
04	Stack Attached To		B. F. of Crusher			
05	Stack Diameter (Meter)		1.0			
06	Flue Gas Temperature (°C)		28			
07	Exit Velocity of Gas (m/sec)		4.5			
08	Flow Rate (Nm³/hr)		12474			
09	Type of Fuel Used		NA*			
10	Analysis	s Results of Flue Gas				
Sl. No.	Parameter(s)	Result(s)	Result(s) Unit(s) Lim			
i.	PM- Particulate Matter	17.4	mg/Nm³	30		

*NA: Not Applicable



NOTE:

- 1. Results reported are valid at the time of and under the prevailing conditions of measurement.
- 2. Results refer only to the particular parameters tested.
- $3. This test report shall not be reproduced except in full, without the written permission of {\tt ENVIROCON}, {\tt Digboi Stores Building}, {\tt New Market}, {\tt Digboi} 786171, {\tt Assam}.$



E-mail: envirocon@rediffmail.com Website: www.envirocon.net.in



Report No.: ENV/HCCL/SE/SEPT/19-20/02

:03/10/2019

W.O.No. : Nil

:11/03/2019

Date

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44 Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

Date

STACK EMISSION TEST RESULTS

01	Stack Emission Test Ref. No.	HCCL/SE/19-20/09-02				
02	Date of Sampling		25.09.2019			
03	Material of Construction		M. S.			
04	Stack Attached To		R.A.B.H.			
05	Stack Diameter (Meter)		3.0			
06	Flue Gas Temperature (°C)	185				
07	Exit Velocity of Gas (m/sec)	14.1				
08	Flow Rate (Nm³/hr)		233486			
09	Type of Fuel Used	NA*				
10	Analysis Resu	lts of Flue Gas		,		
Sl. No.	Parameter(s)	Result(s) Unit(s) Limit(s)				
i.	Particulate Matter (as PM)	19.8 mg/Nm ³ 30				
ii.	Sulphur Dioxide (as SO ₂)	658.5	658.5 mg/Nm ³ 1000			
iii.	Oxides of Nitrogen (as NO _x)	390.6	mg/Nm³	800		

*NA: Not Applicable



NOTE: 1. Results reported are valid at the time of and under the prevailing conditions of measurement.

 $2. \ Results \ refer \ only \ to \ the \ particular \ parameters \ tested.$



E-mail: envirocon@rediffmail.com Website: www.envirocon.net.in



Report No.: ENV/HCCL/SE/SEPT/19-20/03

: 03/10/2019

W.O.No. : Nil

Date : 11/03/2019

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44 Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

Date

STACK EMISSION TEST RESULTS

01	Stack Emission Test Ref. No.	HC	HCCL/SE/19-20/09-03			
02	Date of Sampling		25.09.2019			
03	Material of Construction		M. S.			
04	Stack Attached To		Coal Mill			
05	Stack Diameter (Meter)		1.2			
06	Flue Gas Temperature (°C)		59			
07	Exit Velocity of Gas (m/sec)		12.8			
08	Flow Rate (Nm³/hr)		46784			
09	Type of Fuel Used		Coal			
10	Analysis Res	ults of Flue Gas				
Sl. No.	Parameter(s)	Result(s) Unit(s) Limit(s				
i.	PM- Particulate Matter	28.4 mg/Nm ³ 30				
îi.	Sulphur Dioxide (as SO ₂)	724.9	724.9 mg/Nm ³ 1000			
ili.	Oxides of Nitrogen (as NO _x)	434.6	mg/Nm³	800		



NOTE:

- 1. Results reported are valid at the time of and under the prevailing conditions of measurement.
- 2. Results refer only to the particular parameters tested.
- 3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, Digboi Stores Building, New Market, Digboi 786171, Assam.



E-mail: envirocon@rediffmail.com Website: www.envirocon.net.in



Report No.: ENV/HCCL/SE/SEPT/19-20/04

Date : 03/10/2019

W.O.No. : Nil

Date : 11/03/2019

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44 Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

STACK EMISSION TEST RESULTS

Sl. No.	Parameter(s)	Result(s)				
10	Analysis	s Results of Flue Gas				
09	Type of Fuel Used		NA*			
08	Flow Rate (Nm³/hr)		220222			
07	Exit Velocity of Gas (m/sec)		16.8			
06	Flue Gas Temperature (°C)		231			
05	Stack Diameter (Meter)		2.8			
04	Stack Attached To		Cooler E.S.P.			
03	Material of Construction		M. S.			
02	Date of Sampling		25.092019			
01	Stack Emission Test Ref. No.	НС	HCCL/SE/19-20/09-04			

*NA: Not Applicable



NOTE:

- $1. \ Results \ reported \ are \ valid \ at \ the \ time \ of \ and \ under \ the \ prevailing \ conditions \ of \ measurement,$
- 2. Results refer only to the particular parameters tested.
- 3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, Digboi Stores Building, New Market, Digboi 786171, Assam.



E-mail: envirocon@rediffmail.com Website: www.envirocon.net.in



Report No.: ENV/HCCL/SE/SEPT/19-20/05

Date : 03/10/2019

W. O. No. : Nil

Date : 11/03/2019

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44 Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

STACK EMISSION TEST RESULTS

01	Stack Emission Test Ref. No.	НС	HCCL/SE/19-20/09-05			
02	Date of Sampling		26.09.2019			
03	Material of Construction		M. S.			
04	Stack Attached To		Cement Mill			
05	Stack Diameter (Meter)		1.2			
06	Flue Gas Temperature (°C)		58			
07	Exit Velocity of Gas (m/sec)		13.7			
08	Flow Rate (Nm³/hr)		50225			
09	Type of Fuel Used		NA*			
10	Analysis Results of Flue Gas					
Sl. No.	Parameter(s)	Result(s)	Result(s) Unit(s) Limit(s)			
i.	PM- Particulate Matter	26.2	mg/Nm³	30		

*NA: Not Applicable



Checked By: Mr. Pankaj Baroi, ENVIROCON

NOTE: 1. Results reported are valid at the time of and under the prevailing conditions of measurement.

2. Results refer only to the particular parameters tested.



Digboi Stores Building, New Market Digboi, Assam – 786 171 Ph: 03751-264414, 9435008657, 8876028672 E-mail: envirocon@rediffmail.com

Website: www.envirocon.net.in



Report No.: ENV/HCCL/SE/SEPT/19-20/06

Date : 03/10/2019

W.O.No.: Nil

Date : 11/03/2019

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44 Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

STACK EMISSION TEST RESULTS

Sl. No.	Parameter(s)	Result(s)	Unit(s) mg/Nm³	Limit(s		
10	Analysis Results of Flue Gas					
09	Type of Fuel Used		NA*			
08	Flow Rate (Nm ³ /hr)		22547			
07	Exit Velocity of Gas (m/sec)		12.5			
06	Flue Gas Temperature (°C)		26			
05	Stack Diameter (Meter)		0.8			
04	Stack Attached To		Packing House			
03	Material of Construction		M. S.			
02	Date of Sampling		26.09.2019			
01	Stack Emission Test Ref. No.	НС	HCCL/SE/19-20/09-06			

*NA: Not Applicable



NOTE: 1. Results reported are valid at the time of and under the prevailing conditions of measurement.

2. Results refer only to the particular parameters tested.



E-mail: envirocon@rediffmail.com Website: www.envirocon.net.in



Report No.: ENV/HCCL/ETP/SEPT/19-20/01

:03/10/2019

W.O. No. : Nil

: 11/03/2019 Date

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44 Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

Date

WASTE WATER ANALYSIS RESULTS

: Treated ETP Water Sample Type

Sample Source : ETP Outlet

Collected By: Jointly by Envirocon & Client

Collected On: 26.09.2019

Sl. No.	Parameter(s)	Unit(s)	Result(s)	Desirable Limits (IS: 2490)
01	рH		6.7	5.5 - 9.0
02	Temperature	₀ C	28.2	shall not exceed 5°C above the receiving water temperature
03	Total Suspended Solids	mg/l	15.9	100
04	Biochemical Oxygen Demand (3 Days @27°C)	mg/l	22	30
05	Chemical Oxygen Demand	mg/l	68	250
06	Oil & Grease	mg/l	<0.1	10
07	Total Residual Chlorine	mg/l	<0.01	1.0
08	Ammonical Nitrogen (as N)	mg/l	9.3	50
09	Total Kjeldahl Nitrogen (as NH ₃)	mg/l	22.4	100
10	Free Ammonia (as NH ₃)	mg/l	<0.01	5.0

Analysis Protocol: IS 3025



NOTE:

1. Results reported are valid at the time of and under the prevailing conditions of measurement.

2. Results refer only to the particular parameters tested.