

W.O.No.: Nil

E-mail: envirocon@rediffmail.com Website: www.envirocon.net.in



Report No.: ENV/HCCL/AAQ/MAY/19-20/01

Date : 03/06/2019 Date : 11/03/2019

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44 Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

AMBIENT AIR QUALITY TEST RESULTS

SL. No.	Location(s)	Date of Sampling	PM 2.5 (μg/m³)	PM 10 (μg/m³)	NO ₂ (μg/m ³)	SO ₂ (μg/m³)
	Limit(s)		60 (24 Hrs. Av.)	100 (24 Hrs. Av.)	80 (24 Hrs. Av.)	80 (24 Hrs. Av.)
1.	In-front of Guest House	28.05.2019	15.2	36.5	BDL	BDL
2.	Near Crusher Area	28.05.2019	27.3	58.9	BDL	BDL
3.	In- Front of Compressor House (Cement Mill)	29.05.2019	22.4	52.4	7.1	BDL
4.	Near ETP	29.05.2019	19.4	47.6	5.2	BDL

Analysis Protocol: IS 5182 BDL: Below Detectable Level



Checked By: Mr. Pankaj Baroi, ENVIROCON

- 2. Results refer only to the particular parameters tested.
- $3.\ This test report shall not be reproduced except in full, without the written permission of ENVIROCON, Digboi Stores Building, New Market, Digboi 786171, Assam.$



W.O.No.: Nil

: 11/03/2019

Date

E-mail: envirocon@rediffmail.cor Website: www.envirocon.net.in



Report No.: ENV/HCCL/SE/MAY/19-20/01

: 03/06/2019

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44 Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

Date

STACK EMISSION TEST RESULTS

01	Stack Emission Test Ref. No.	HCCL/SE/19-20/05-01		
02	Date of Sampling	28.05.2019		
03	Material of Construction	M. S.		
04	Stack Attached To	B. F. of Crusher		
05	Stack Diameter (Meter)	1.0		
06	Flue Gas Temperature (°C)	31		
07	Exit Velocity of Gas (m/sec)	4.3		
08	Flow Rate (Nm³/hr)	11920		
09	Type of Fuel Used	NA*		
10	Analysis Results of Flue Gas			
Sl. No.	Parameter(s)	Result(s)	Unit(s)	Limit(s)
i.	PM- Particulate Matter	21.6 mg/Nm ³ 30		

*NA: Not Applicable



Checked By: Mr. Pankaj Baroi, ENVIROCON

- 2. Results refer only to the particular parameters tested.
- $3.\ This test report shall not be reproduced except in full, without the written permission of ENVIROCON, Digboi Stores Building, New Market, Digboi 786171, Assam.$



Website: www.envirocon.net.in



Report No.: ENV/HCCL/SE/MAY/19-20/02

W.O.No.: Nil :03/06/2019 : 11/03/2019 **Date**

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44 Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

Date

STACK EMISSION TEST RESULTS

01	Stack Emission Test Ref. No.	HCCL/SE/19-20/05-02		
02	Date of Sampling	28.05.2019		
03	Material of Construction		M. S.	
04	Stack Attached To		R.A.B.H.	
05	Stack Diameter (Meter)	3.0		
06	Flue Gas Temperature (°C)	179		
07	Exit Velocity of Gas (m/sec)	14.3		
08	Flow Rate (Nm³/hr)	239941		
09	Type of Fuel Used	NA*		
10	Analysis Results of Flue Gas			
Sl. No.	Parameter(s)	Result(s)	Unit(s)	Limit(s)
i.	Particulate Matter (as PM)	21.7	mg/Nm³	30
ii.	Sulphur Dioxide (as SO ₂)	779.47	mg/Nm³	1000
iii.	Oxides of Nitrogen (as NO _x)	391.04 mg/Nm³ 800		

*NA: Not Applicable



Checked By: Mr. Pankaj Baroi, ENVIROCON

- 2. Results refer only to the particular parameters tested.
- $3.\ This test report shall not be reproduced except in full, without the written permission of ENVIROCON, Digboi Stores Building, New Market, Digboi 786171, Assam.$



W.O.No.: Nil

Date

: 11/03/2019

E-mail: envirocon@rediffmail.cor Website: www.envirocon.net.in



Report No.: ENV/HCCL/SE/MAY/19-20/03

Date : 03/06/2019

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44 Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

STACK EMISSION TEST RESULTS

01	Stack Emission Test Ref. No.	HCCL/SE/19-20/05-03			
02	Date of Sampling	28.05.2019			
03	Material of Construction	M. S.			
04	Stack Attached To	Coal Mill			
05	Stack Diameter (Meter)	1.2			
06	Flue Gas Temperature (°C)	56			
07	Exit Velocity of Gas (m/sec)	8.8			
08	Flow Rate (Nm ³ /hr)	32457			
09	Type of Fuel Used	Coal			
10	Analysis Results of Flue Gas				
Sl. No.	Parameter(s)	Result(s)	Unit(s)	Limit(s)	
i.	PM- Particulate Matter	27.3	mg/Nm³	30	
ii.	Sulphur Dioxide (as SO ₂)	827.53	mg/Nm³	1000	
iii.	Oxides of Nitrogen (as NO _x)	540.24 mg/Nm ³ 800			



Checked By: Mr. Pankaj Baroi, ENVIROCON

- 2. Results refer only to the particular parameters tested.
- $3.\ This test report shall not be reproduced except in full, without the written permission of ENVIROCON, Digboi Stores Building, New Market, Digboi 786171, Assam.$



W.O.No.: Nil

Date

: 11/03/2019

E-mail: envirocon@rediffmail.com Website: www.envirocon.net.in



Report No.: ENV/HCCL/SE/MAY/19-20/04

Date : 03/06/2019

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44 Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

STACK EMISSION TEST RESULTS

01	Stack Emission Test Ref. No.	HCCL/SE/19-20/05-04			
02	Date of Sampling	29.05.2019			
03	Material of Construction	M. S.			
04	Stack Attached To	Cooler E.S.P.			
05	Stack Diameter (Meter)	2.8			
06	Flue Gas Temperature (°C)	219			
07	Exit Velocity of Gas (m/sec)	13.1			
08	Flow Rate (Nm³/hr)	175909			
09	Type of Fuel Used	NA*			
10	Analysis Results of Flue Gas				
Sl. No.	Parameter(s)	Result(s)	Unit(s)	Limit(s)	
i.	PM- Particulate Matter	19.8 mg/Nm ³ 30			

*NA: Not Applicable



Checked By: Mr. Pankaj Baroi, ENVIROCON

- 2. Results refer only to the particular parameters tested.
- $3.\ This test report shall not be reproduced except in full, without the written permission of ENVIROCON, Digboi Stores Building, New Market, Digboi 786171, Assam.$



W.O.No.: Nil

: 11/03/2019

Date

E-mail: envirocon@rediffmail.com Website: www.envirocon.net.in



Report No.: ENV/HCCL/SE/MAY/19-20/05

: 03/06/2019

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44 Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

Date

STACK EMISSION TEST RESULTS

01	Stack Emission Test Ref. No.	HCCL/SE/19-20/05-05			
02	Date of Sampling	29.05.2019			
03	Material of Construction	M. S.			
04	Stack Attached To	Cement Mill			
05	Stack Diameter (Meter)	1.2			
06	Flue Gas Temperature (°C)	61			
07	Exit Velocity of Gas (m/sec)	11.2			
08	Flow Rate (Nm³/hr)	40691			
09	Type of Fuel Used	NA*			
10	Analysis Results of Flue Gas				
Sl. No.	Parameter(s)	Result(s)	Unit(s)	Limit(s)	
i.	PM- Particulate Matter	27.9 mg/Nm ³ 30			

*NA: Not Applicable



Checked By: Mr. Pankaj Baroi, ENVIROCON

- 2. Results refer only to the particular parameters tested.
- $3.\ This test report shall not be reproduced except in full, without the written permission of ENVIROCON, Digboi Stores Building, New Market, Digboi 786171, Assam.$



W.O.No.: Nil

: 11/03/2019

Date

Website: www.envirocon.net.in



Report No.: ENV/HCCL/SE/MAY/19-20/06

Date : 03/06/2019

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44 Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

STACK EMISSION TEST RESULTS

01	Stack Emission Test Ref. No.	HCCL/SE/19-20/05-06			
02	Date of Sampling	29.05.2019			
03	Material of Construction	M. S.			
04	Stack Attached To	Packing House			
05	Stack Diameter (Meter)	0.8			
06	Flue Gas Temperature (°C)	25			
07	Exit Velocity of Gas (m/sec)	12.4			
08	Flow Rate (Nm³/hr)	22441			
09	Type of Fuel Used	NA*			
10	Analysis Results of Flue Gas				
Sl. No.	Parameter(s)	Result(s)	Unit(s)	Limit(s)	
i.	PM- Particulate Matter	25.3 mg/Nm³ 30			

*NA: Not Applicable



Checked By: Mr. Pankaj Baroi, ENVIROCON

- 2. Results refer only to the particular parameters tested.
- $3.\ This test report shall not be reproduced except in full, without the written permission of ENVIROCON, Digboi Stores Building, New Market, Digboi 786171, Assam.$