

HCCL/MSPCB/20-21/02

Date: 22/1/21.

To,
The Member Secretary,
Meghalaya State Pollution Control Board
ARDEN Lumpyngngad

Shillong (Meghalaya) -793014

Subject: Reports on Ambient air quality test results, Stack Emission Test Results & Waste Water Analysis (STP) for the month of **Nov 2020**

Dear Sir,

Please find enclosed herewith to this letter the reports for the month of **Nov 2020** for the following test results:

Sl No.	Test Results	Purpose	
1	Ambient air quality	-	
2	Stack Emission	B.F of Crusher	
3	Stack Emission	R.A.B.H	
4	Stack Emission	Coal Mill	
5	Stack Emission	Cooler E.S.P	
6	Stack Emission	Cement Mill	
7	Stack Emission	Packing House	
8	Waste Water Analysis Result	Treated STP Water Analysis	

Thanking you,

For Hills Cement Company Ltd

Authorised Signatory "

Copy To: - The Joint Director (S), Ministry of Environment, Forest & Climate Change NE Regional Office, Lumbatngen, Shillong 793021 for information



HCCL/MSPCB/20-21/02

Date: 22/0//2/

To, The Member Secretary, Meghalaya State Pollution Control Board ARDEN Lumpyngngad Shillong (Meghalaya) -793014

Subject: Reports on Ambient air quality test results, Stack Emission Test Results & Waste Water Analysis (STP) for the month of Nov 2020

Dear Sir.

Please find enclosed herewith to this letter the reports for the month of Nov 2020 for the following test results:

<u>S1 No.</u>	Test Results	Purpose
1	Ambient air quality	-
2	Stack Emission	B.F of Crusher
3	Stack Emission	R.A.B.H
4	Stack Emission	Coal Mill
5	Stack Emission	Cooler E.S.P
6	Stack Emission	Cement Mill
7	Stack Emission	Packing House
8	Waste Water Analysis Result	Treated STP Water Analysis

Thanking you,

For Hills Cement Company Ltd HILLS CEMENT CO. LTD.

Copyring The Joint Director (S), Ministry of Environment, Forest & Climate Cha

NE Regional Office, Lumbatngen, Shillong 793021 for informatio



PCB, Assam & MSPCB, Meghalaya

Digboi Stores Building, New Market Digboi, Assam - 786 171 Ph: 03751-264414, 9435008657, 8876028672

E-mail: envirocon@rediffmail.com Website: www.envirocon.net.in



Report No.: ENV/HCCL/AAQ/NOV/20-21/01

Date :09/12/2020 W. O. No. : Date

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44 Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

AMBIENT AIR QUALITY TEST RESULTS

SL.	Location(s)	Limit(s) Date of Sampling		PM 10 (μg/m³)	SO ₂ (μg/m³)	NO ₂ (μg/m³)
No.				100 (24 Hrs. Av.)	80 (24 Hrs. Av.)	80 (24 Hrs. Av.)
1.	In-front of Guest House	22.11.2020	19.6	35.7	<1.0	<1.0
2.	Near Crusher Area	22.11.2020	39.4	76.8	3.1	5.6
3.	In- Front of Compressor House (Cement Mill)	23.11.2020	30.2	64.2	3.6	6.4
4.	Near Mines	23.11.2020	44.6	83.6	1.9	2.2

Analysis Protocol: IS 5182



- 1. Results reported are valid at the time of and under the prevailing conditions of measurement.
- 2. Results refer only to the particular parameters tested.
- 3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, Digboi Stores Building, New Market, Digboi 786171, Assam.



Digboi Stores Building, New Market
Digboi, Assam - 786 171
Ph: 03761-264414, 9436008667, 8876028672

E-mail: envirocon@rediffmail.com Website: www.envirocon.net.in



Report No. : ENV/HCCL/FE/NOV/2020-21/01

Date : 09/12/2020

W. O. No. : HCCL/HO/ENV/20-21/01

Date : 18/11/2020

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44 Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

PROCESS FUGITIVE EMISSION TEST RESULTS

Date	Locations	Fugitive Emission Results for SPM (µg/m³)	Limits (µg/m³)
22.11.2020	Coal Storage Section	712	2000
23.11.2020	Lime Stone Storage Section	1621	5000
2.11.2020	Fly-ash Storage Section	2648	5000
23.11.2020	Cement Packing Section	3204	5000



Checked By: Mr. Pankaj Baroi, ENVIROCON

- 1. Results reported are valid at the time of and under the prevailing conditions of measurement.
- 2. Results refer only to the particular parameters tested.
- 3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, Digboi Stores Building, New Market, Digboi 786171, Assam.



PCB, Assam & MSPCB, Meghalaya

Digboi Stores Building, New Market Digboi, Assam - 786 171 Ph: 03751-264414, 9435008657, 8876028672

E-mail: envirocon@rediffmail.com Website: www.envirocon.net.in



Report No.: ENV/HCCL/SE/NOV/20-21/01

: 09/12/2020

W. O. No. : Date

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44 Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

Date

STACK EMISSION TEST RESULTS

Sl. No.	Parameter(s)	Result(s)	Unit(s)	Limit(s)	
10	Analysi	s Results of Flue Gas			
09	Type of Fuel Used	NA*			
08	Flow Rate (Nm³/hr)	14937.22			
07	Exit Velocity of Gas (m/sec)	5.3			
06	Flue Gas Temperature (°C)	26			
05	Stack Diameter (Meter)	1.0			
04	Stack Attached To	B. F. of Crusher			
03	Material of Construction		M. S.		
02	Date of Sampling		22.11.2020		
01	Stack Emission Test Ref. No.	HCCL/SE/20-21/11-01			

*NA: Not Applicable



- 1. Results reported are valid at the time of and under the prevailing conditions of measurement.
- 2. Results refer only to the particular parameters tested.
- 3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, Digboi Stores Building, New Market, Digboi 786171, Assam.



Digboi Stores Building, New Market Digboi, Assam – 786 171 Ph: 03751-264414, 9435008657, 8876028672

E-mail: envirocon@rediffmail.com Website: www.envirocon.net.in



Report No.: ENV/HCCL/SE/NOV/20-21/02

Date : 09/12/2020

W. O. No.

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44 Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

STACK EMISSION TEST RESULTS

01	Stack Emission Test Ref. No.	HCCL/SE/20-21/11-02			
02	Date of Sampling		22.11.2020		
03	Material of Construction		M. S.		
04	Stack Attached To		R.A.B.H.		
05	Stack Diameter (Meter)		3.0		
06	Flue Gas Temperature (°C)	178			
07	Exit Velocity of Gas (m/sec)		16.4		
08	Flow Rate (Nm³/hr)	275787.62			
09	Type of Fuel Used	NA*			
10	Analysi	s Results of Flue Gas			
SI. No.	Parameter(s)	Result(s)	Unit(s)	Limit(s)	
i.	Particulate Matter (as PM)	16.1	mg/Nm³	30	
ii.	Sulphur Dioxide (as SO ₂)	723.4	mg/Nm³	1000	
iii.	Oxides of Nitrogen (as NO _x)	522.6	mg/Nm³	800	

^{*}NA: Not Applicable



NOTE: 1. Results reported are valid at the time of and under the prevailing conditions of measurement.

2. Results refer only to the particular parameters tested.

3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, Digboi Stores Building, New Market, Digboi - 786171, Assam.



Digboi Stores Building, New Market Digboi, Assam – 786 171 Ph: 03751-264414, 9435008657, 8876028672 E-mail: envirocon@rediffmail.com

E-mail: envirocon@rediffmail.co
Website: www.envirocon.net.in



Report No.: ENV/HCCL/SE/NOV/20-21/03

:09/12/2020

W. O. No. :

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44 Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

Date

STACK EMISSION TEST RESULTS

01	Stack Emission Test Ref. No.	нс	HCCL/SE/20-21/11-03			
02	Date of Sampling		22.11.2020			
03	Material of Construction		M. S.			
04	Stack Attached To		Coal Mill			
05	Stack Diameter (Meter)		1.2			
06	Flue Gas Temperature (°C)		61			
07	Exit Velocity of Gas (m/sec)		14.1			
08	Flow Rate (Nm³/hr)		51227.14			
09	Type of Fuel Used		Coal			
10	Analysi	s Results of Flue Gas				
Sl. No.	Parameter(s)	Result(s)	Unit(s)	Limit(s)		
j.	PM- Particulate Matter	21.1	mg/Nm³	30		
ii.	Sulphur Dioxide (as SO ₂)	826.7	mg/Nm³	1000		
iii.	Oxides of Nitrogen (as NO _x)	613.9	mg/Nm³	800		



- 1. Results reported are valid at the time of and under the prevailing conditions of measurement.
- 2. Results refer only to the particular parameters tested.
- 3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, Digboi Stores Building, New Market, Digboi 786171, Assam.



Digboi Stores Building, New Market
Digboi, Assam – 786 171
Ph: 03751-264414, 9435008657, 8876028672
E-mail: envirocon@rediffmail.com
Website: www.envirocon.net.in



Report No.: ENV/HCCL/SE/NOV/20-21/04

Date : 09/12/2020

W. O. No. :

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44 Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

STACK EMISSION TEST RESULTS

SI. No.	Parameter(s)	Result(s)	Unit(s)	Limit(s)	
10	Analysi	s Results of Flue Gas			
09	Type of Fuel Used	NA*			
08	Flow Rate (Nm³/hr)	204008.9			
07	Exit Velocity of Gas (m/sec)	15.1			
06	Flue Gas Temperature (°C)	216			
05	Stack Diameter (Meter)	2.8			
04	Stack Attached To		Cooler E.S.P.		
03	Material of Construction		M. S.		
02	Date of Sampling		23.11.2020		
01	Stack Emission Test Ref. No.	HCCL/SE/20-21/11-04			

*NA: Not Applicable



NOTE: 1. Results reported are valid at the time of and under the prevailing conditions of measurement.

2. Results refer only to the particular parameters tested.

3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, Digboi Stores Building, New Market, Digboi – 786171, Assam.



Digboi Stores Building, New Market Digboi, Assam - 786 171 Ph: 03751-264414, 9435008657, 8876028672 E-mail: envirocon@rediffmail.com

Website: www.envirocon.net.in



Report No.: ENV/HCCL/SE/NOV/20-21/05

Date : 09/12/2020 W. O. No. Date

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44 Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

STACK EMISSION TEST RESULTS

SI. No.	Parameter(s)	Result(s)	Unit(s)	Limit(s)	
10	Analysi	s Results of Flue Gas			
09	Type of Fuel Used	NA*			
08	Flow Rate (Nm³/hr)	46053.21			
07	Exit Velocity of Gas (m/sec)	12.6			
06	Flue Gas Temperature (°C)	59			
05	Stack Diameter (Meter)	1.2			
04	Stack Attached To	Cement Mill			
03	Material of Construction		M. S.		
02	Date of Sampling		23.11.2020		
01	Stack Emission Test Ref. No.	HCCL/SE/20-21/11-05			

*NA: Not Applicable



NOTE: 1. Results reported are valid at the time of and under the prevailing conditions of measurement.

2. Results refer only to the particular parameters tested.



Digboi Stores Building, New Market Digboi, Assam – 786 171 Ph: 03751-264414, 9435008657, 8876028672

E-mail: envirocon@rediffmail.com Website: www.envirocon.net.in



Report No.: ENV/HCCL/SE/NOV/20-21/06

Date : 09/12/2020

W. O. No. :

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44 Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

STACK EMISSION TEST RESULTS

SI. No.	Parameter(s)	Result(s)	Unit(s)	Limit(s)	
10	Analysi	lysis Results of Flue Gas			
09	Type of Fuel Used	NA*			
08	Flow Rate (Nm³/hr)	24050.67			
07	Exit Velocity of Gas (m/sec)	13.2			
06	Flue Gas Temperature (°C)	23			
05	Stack Diameter (Meter)	0.8			
04	Stack Attached To		Packing House		
03	Material of Construction		M. S.		
02	Date of Sampling		23.11.2020		
01	Stack Emission Test Ref. No.	HCCL/SE/20-21/11-06			

*NA: Not Applicable



NOTE: 1. Results reported are valid at the time of and under the prevailing conditions of measurement.

2. Results refer only to the particular parameters tested.

3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, Digboi Stores Building, New Market, Digboi – 786171, Assam.



Recognised By PCB, Assam & MSPCB, Meghalaya

Digboi Stores Building, New Market Digboi, Assam – 786 171 Ph: 03751-264414, 9435008657, 8876028672

E-mail: envirocon@rediffmail.com Website: www.envirocon.net.in



Report No.: ENV/HCCL/SW/NOV/20-21/01

Date : 09/12/2020

W. O. No.

Date

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44 Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

WASTE WATER ANALYSIS RESULTS

Sample Type : STP Treated Water Sample Source : STP Outlet

Collected By : Jointly by Envirocon & Client

Collected On : 23.11.2020

Sl. No.	Parameter(s)	Unit(s)	Result(s)	Desirable Limit (CPCB Norms)
1.	рН	-	6.83	5.5 - 9.0
2.	Temperature	°C	22.1	shall not exceed 5°C above the receiving water temperature
3.	Total Suspended Solids	mg/l	22	100
4.	Biochemical Oxygen Demand (3 Days @27°C)	mg/l	24	30
5.	Chemical Oxygen Demand	mg/l	91	250
6.	Oil & Grease	mg/l	0.36	10
7.	Total Residual Chlorine	mg/l	<0.01	1.0
8.	Ammonical Nitrogen (as N)	mg/l	3.6	50
9.	Total Kjeldahl Nitrogen (as NH ₃)	mg/l	14.1	100
10.	Free Ammonia (as NH ₃)	mg/l	<0.01	5.0

Analysis Protocol: IS 3025 ND: Not Detected



- 1. Results reported are valid at the time of and under the prevailing conditions of measurement.
- 2. Results refer only to the particular parameters tested.
- 3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, Digboi Stores Building, New Market, Digboi 786171, Assam.