

Website: www.tajcement.com CIN: U26942ML2003PLC007295

HCCL/MSPCB/23-24/007

Date: 07/09/2023

To,

The Member Secretary,
Meghalaya State Pollution Control Board
ARDEN Lumpyngngad
Shillong (Meghalaya) -793014

Subject: Reports on Ambient Air Quality test, Stack Emission test, Waste Water
Analysis (STP) & Noise Level Measurement Test for the month of July 2023

Dear Sir,

Please find enclosed herewith to this letter the reports for the month of July 2023 for the following test results:

SI No.	Test Results	Purpose
I	Ambient Air Quality	-
2	Stack Emission	R.A.B.H
3	Stack Emission	Coal Mill
4	Stack Emission	Cooler E.S.P
5	Waste Water Analysis Result	STP Water Analysis
6	Noise Level Measurement Test	

Thanking you,

HILLS CEMENT COMPANY LTD

Tyash Baid .
Authorised Signatory

Authorised Signatory

Copy To: - (1) The Joint Director (S), Ministry of Environment, Forest & Climate Change

NE Regional Office, Lumbatngen, Shillong 793021 for information

(2) The Regional Director Regional Directorate (NE), Central Pollution Control Board, TUM-SIR, Lower Motinagar, Near Fire Brigrade HQ, Shillong-793014

HILLS CEMENT COMPANY LIMITED







Website: www.tajcement.com CIN: U26942ML2003PLC007295

Date: 07/09. 2023

HCCL/MSPCB/23-24/008

To.

The Member Secretary,

Meghalaya State Pollution Control Board

ARDEN Lumpyngngad

Shillong (Meghalaya) -793014

Subject: Reports on Ambient Air Quality test, Stack Emission test, Waste Water Analysis (STP) & Noise Level Measurement Test for the month of July 2023 Dear Sir,

Please find enclosed herewith to this letter the reports for the month of July 2023 for the following test results:

SI No.	Test Results	Purpose
1	Ambient Air Quality	-
2	Stack Emission	R.A.B.H
3	Stack Emission	Coal Mill
4	Stack Emission	Cooler E.S.P
5	Waste Water Analysis Result	STP Water Analysis
6	Noise Level Measurement Test	

Thanking you,

For Hills Cement Company Ltd

HILLS CEMENT COMPANY LTD.

Authorised Signatory
Authorised Signatory

Copy To: - (1) The Joint Director (S), Ministry of Environment, Forest & Climate Change

> NE Regional Office, Lumbatngen, Shillong 793021 for information (2) The Regional Director Regional Directorate (NE), Central Pollution Control Board, TUM-SIR, Lower Motinagar, Near Fire Brigrade HQ, Shillong-793014



O/C MOEFIC





HCCL/MSPCB/23-24/009

Ton The Member Secretary, Meghalaya State Pollution Control Board ARDEN Lumpyngngad Shillong (Meghalaya) -793014

Subject: Reports on Ambient Air Quality test, Stack Emission test, Waste Water Analysis (STP) & Noise Level Measurement Test for the month of July 2023 Dear Sir,

Please find enclosed herewith to this letter the reports for the month of July 2023 for the following test results:

Sl No.	Test Results	Purpose
1	Ambient Air Quality	
2	Stack Emission	R.A.B.H
3	Stack Emission	Coal Mill
4	Stack Emission	Cooler E.S.P
5	Waste Water Analysis Result	STP Water Analysis
6	Noise Level Measurement Test	

Thanking you,

For Hills Cement Company Ltd

HILLS CEMENT COMPANY LTD. Typola Beid

Authorised Signatory Signatory

Copy To: - (1) The Joint Director (S), Ministry of Environment, Forest & Climate Change

NE Regional Office, Lumbatngen, Shillong 793021 for information

(2) The Regional Director Regional Directorate (NE), Central Pollution Control Board, TUM-SIR, Lower Motinagar, Near Fire Brigrade HQ, Shillong-793014



ISO 9001:2015 Certified ISO 45001:2018 Certified

E-mail: envirocon@rediffmail.com

Report No.: ENV/HCCL/23-24/AA-07/01 Order No.: HCCL/HO/ENV/21-22/01

Date : 10/08/2023 Date : 08/04/2021

Report Issued To: HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44, Sub Division: Khliehriat, Dist.: Jaintia Hills, Meghalaya

AMBIENT AIR QUALITY TEST RESULTS

Sl. No.	LOCATION(S) ↓	Date of Sampling	PM 2.5 (μg/m³)	PM 10 (μg/m³)	SO ₂ (μg/m³)	NO ₂ (μg/m³)
	LIMIT(S) →		60	100	80	80
01	In-front of Guest House	27.07.2023	28.7	56.2	<5.0	<6.0
02	Near Crusher Area	27.07.2023	39.2	58.3	8.2	8.8
03	In- Front of Compressor House (Cement Mill)	28.07.2023	38.4	56.8	7.9	8.5
04	Near Mines	28.07.2023	31.6	50.7	<5.0	<6.0

Analysis Protocol: IS 5182



Checked By: Mr. Pankaj Baroi, ENVIROCON

NOTE: 1. Results reported are valid at the time of and under the prevailing conditions of measurement.

- 2. Results refer only to the particular parameters tested.
- $3.\ This test report shall not be reproduced except in full, without the written permission of ENVIROCON, I.O.C.L (AOD) New Market, Digboi 786171, Assam.$

Core Services: Environmental Monitoring & Data Generation, EIA & EMP, Environmental Audit & Allied Environmental Management jobs

Associate Services: Certification by Competent Person (CIF), NDT, Hydraulic Testing, Chartered Engineer Services etc.



Envirocon Building, I.O.C.L (AOD) New Market P.O.: Digboi, Dist.: Tinsukia, Assam – 786 171 Ph: 03751-264414, 9435008657, 8876028672 E-mail: envirocon@rediffmail.com

ISO 9001:2015 Certified ISO 45001:2018 Certified

,

Report No.: ENV/HCCL/23-24/N-07/01 Order No.: HCCL/HO/ENV/21-22/01

Date : 10/08/2023 Date : 08/04/2021

Report Issued To: HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44, Sub Division: Khliehriat, Dist.: Jaintia Hills, Meghalaya

NOISE LEVEL MEASUREMENT RESULTS

CL N	()	Date	Day Time		Night Time	
Sl. No.	Location(s)	Of Measurement	L _{eq} (dB-A)	Limit (dB-A)	L _{eq} (dB-A)	Limit (dB-A)
1	In-front of Guest House	27.07.2023	51.4	75	46.8	70
2	Near Crusher Area	27.07.2023	68.2	75	62.7	70
3	In- Front of Compressor House (Cement Mill)	28.07.2023	67.8	75	62.5	70
4	Near Mines	28.07.2023	56.4	75	47.2	70



Checked By: Mr. Pankaj Baroi, ENVIROCON

NOTE: 1. Results reported are valid at the time of and under the prevailing conditions of measurement.

- 2. Results refer only to the particular parameters tested.
- 3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, I.O.C.L (AOD) New Market, Digboi 786171, Assam.

E-mail: envirocon@rediffmail.com

ISO 9001:2015 Certified ISO 45001:2018 Certified

Report No.: ENV/HCCL/23-24/SE-07/01 Order No.: HCCL/HO/ENV/21-22/01

Date : 10/08/2023 Date : 08/04/2021

Report Issued To: HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44, Sub Division: Khliehriat, Dist.: Jaintia Hills, Meghalaya

STACK EMISSION TEST RESULTS

01	Test Ref. No.	HCCL/2023/SE-07/01			
02	Date of Sampling	27.07.2023			
03	Material of Construction		M. S.		
04	Stack Attached To		R.A.B.H.		
05	Stack Diameter (Meter)	3.0			
06	Flue Gas Temperature (°C)	174			
07	Exit Velocity of Gas (m/sec)	15.9			
08	Flow Rate (Nm³/hr)	269772			
09	Type of Fuel Used	NA*			
	Analysis Resul	lts of Flue Gas			
Sl. No.	Parameter(s)	Result(s)	Unit(s)	Limit(s)	
i.	Particulate Matter	24 mg/Nm³ 30			
ii.	Sulphur Dioxide (as SO ₂)	760 mg/Nm ³ 1000			
iii.	Oxides of Nitrogen (as NO _x)	271 mg/Nm ³ 800			

^{*}NA: Not Applicable



Checked By: Mr. Pankaj Baroi, ENVIROCON

NOTE: 1. Results reported are valid at the time of and under the prevailing conditions of measurement.

- 2. Results refer only to the particular parameters tested.
- $3.\ This test report shall not be reproduced except in full, without the written permission of ENVIROCON, I.O.C.L (AOD) New Market, Digboi 786171, Assam.$

E-mail: envirocon@rediffmail.com

ISO 9001:2015 Certified ISO 45001:2018 Certified

Report No.: ENV/HCCL/23-24/SE-07/02 Order No.: HCCL/HO/ENV/21-22/01

Date : 10/08/2023 Date : 08/04/2021

Report Issued To: HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44, Sub Division: Khliehriat, Dist.: Jaintia Hills, Meghalaya

STACK EMISSION TEST RESULTS

01	Test Ref. No.	HCCL/2023/SE-07/02				
02	Date of Sampling	27.07.2023				
03	Material of Construction	M. S.				
04	Stack Attached To		Coal Mill			
05	Stack Diameter (Meter)		1.2			
06	Flue Gas Temperature (°C)	59				
07	Exit Velocity of Gas (m/sec)	11.4				
08	Flow Rate (Nm³/hr)	41667				
09	Type of Fuel Used	Coal				
	Analysis Resul	lts of Flue Gas				
Sl. No.	Parameter(s)	Result(s)	Unit(s)	Limit(s)		
i.	Particulate Matter	26 mg/Nm³ 30				
ii.	Sulphur Dioxide (as SO ₂)	601 mg/Nm³ 1000				
iii.	Oxides of Nitrogen (as NO _x)	208	208 mg/Nm ³ 800			



Checked By: Mr. Pankaj Baroi, ENVIROCON

NOTE: 1. Results reported are valid at the time of and under the prevailing conditions of measurement.

2. Results refer only to the particular parameters tested.

3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, I.O.C.L (AOD) New Market, Digboi - 786171, Assam.

E-mail: envirocon@rediffmail.com

ISO 9001:2015 Certified ISO 45001:2018 Certified

Report No.: ENV/HCCL/23-24/SE-07/03 Order No.: HCCL/HO/ENV/21-22/01

Date : 10/08/2023 Date : 08/04/2021

Report Issued To: HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44, Sub Division: Khliehriat, Dist.: Jaintia Hills, Meghalaya

STACK EMISSION TEST RESULTS

01	Test Ref. No.	HCCL/2023/SE-07/03			
02	Date of Sampling	27.07.2023			
03	Material of Construction		M. S.		
04	Stack Attached To		Cooler E.S.P.		
05	Stack Diameter (Meter)	2.8			
06	Flue Gas Temperature (°C)	219			
07	Exit Velocity of Gas (m/sec)	10.8			
08	Flow Rate (Nm³/hr)	145024			
09	Type of Fuel Used	NA*			
	Analysis Resul	ts of Flue Gas			
Sl. No.	Parameter(s)	Result(s)	Unit(s)	Limit(s)	
i.	Particulate Matter	23 mg/Nm³ 30			
ii.	Sulphur Dioxide (as SO ₂)	BDL# mg/Nm³ 1000			
iii.	Oxides of Nitrogen (as NO _x)	BDL#	mg/Nm³	800	

*NA: Not Applicable

#BDL: Below Detectable Limit



Checked By: Mr. Pankaj Baroi, ENVIROCON

NOTE: 1. Results reported are valid at the time of and under the prevailing conditions of measurement.

2. Results refer only to the particular parameters tested.

3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, I.O.C.L (AOD) New Market, Digboi - 786171, Assam.

E-mail: envirocon@rediffmail.com

ISO 9001:2015 Certified ISO 45001:2018 Certified

Report No.: ENV/HCCL/23-24/WW-07/01 Order No.: HCCL/HO/ENV/21-22/01

Date : 10/08/2023 Date : 08/04/2021

Report Issued To: HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44, Sub Division: Khliehriat, Dist.: Jaintia Hills, Meghalaya

WASTE WATER ANALYSIS RESULTS

Sample Ref. No. : HCCL/2023/WW-2907/01

Sample Type/Source : Waste Water (Treated)/STP Outlet Sample Collected By : Representative of ENVIROCON

Sample Collected On : 29.07.2023 Sample Received On : 31.07.2023 Analysis Protocol : IS 3025

Sl. No.	Parameter(s)	Unit(s)	Result(s)	Limit (As Per CPCB Standards)
1.	рН		7.23	5.5 – 9.0
2.	Temperature	°C	26.4	shall not exceed 5°C above the receiving water temperature
3.	Total Suspended Solids	mg/l	27	100
4.	Biochemical Oxygen Demand	mg/l	17	30
5.	Chemical Oxygen Demand	mg/l	82	250
6.	Oil & Grease	mg/l	<4.0	10
7.	Total Residual Chlorine	mg/l	<0.01	1.0
8.	Ammonical Nitrogen (as N)	mg/l	2.1	50
9.	Total Kjeldahl Nitrogen (as NH ₃)	mg/l	9.6	100
10.	Free Ammonia (as NH ₃)	mg/l	<0.01	5.0



Checked By: Mr. Pankaj Baroi, ENVIROCON

NOTE: 1. Results reported are valid at the time of and under the prevailing conditions of measurement.

- 2. Results refer only to the particular parameters tested.
- $3.\ This test report shall not be reproduced except in full, without the written permission of ENVIROCON, I.O.C.L (AOD) New Market, Digboi 786171, Assam.$