

HCCL/MSPCB/19-20/06

Date: 21th Feb 2020

To,

The Member Secretary,

Meghalaya State Pollution Control Board

ARDEN Lumpyngngad

Shillong (Meghalaya) -793014

Subject: Reports on Ambient air quality test results, Stack Emission Test Results & Waste Water Analysis (STP) for the month of Jan 2020

Dear Sir,

Please find enclosed herewith to this letter the reports for the month of Jan 2020 for the following test results:

SI No.	Test Results	Purpose	
1	Ambient air quality		
2	Stack Emission	B.F of Crusher	
3	Stack Emission	R.A.B.H	
4	Stack Emission	Coal Mill	
5	Stack Emission	Cooler E.S.P	
6	Stack Emission	Cement Mill	
7	Stack Emission	Packing House	
8 .	Waste Water Analysis Result	Treated STP Water	

Thanking you,

For Hills Cement Company Ltd HILLS CEMENT CO. LTD.

Authorised Signatory
Copy To: The Joint Director (S), Ministry of Environment, Forest & Climate Change
NE Regional Office, Lumbatngen, Shillong 793021 for information

HILLS CEMENT COMPANY LTD.



HCCL/MSPCB/19-20/06

Date: 21th Feb 2020

To,
The Member Secretary,
Meghalaya State Pollution Control Board
ARDEN Lompyngngad
Shillong (Meghalaya) -793014

Subject: Reports on Ambient air quality test results, Stack Emission Test Results & Waste Water Analysis (STP) for the month of Jan 2020

Dear Sir,

Please find enclosed herewith to this letter the reports for the month of Jan 2020 for the following test results:

SI No.	Test Results	Purpose	
1	Ambient air quality	ity -	
2	Stack Emission	B.F of Crusher	
3	Stack Emission	R.A.B.H	
4	Stack Emission	Coal Mill	
5	Stack Emission	Cooler E.S.P	
6	Stack Emission	Cement Mill	
7	Stack Emission	Packing House	
8.	Waste Water Analysis Result	Treated STP Water	

Thanking you,

For Hills Cement Company Ltd HILLS CEMENT CO. LTD.

Copy To: The Joint Director (S), Ministry of Environment, Forest & Climate Change

NE Regional Office, Lumbatngen, Shillong 793021 for information





Digboi Stores Building, New Market
Digboi, Assam – 786 171
Ph: 03751-264414, 9435008657, 8876028672
E-mail: envirocon@rediffmail.com
Website: www.envirocon.net.in



Report No.: ENV/HCCL/AAQ/JAN/19-20/01

Date : 10/01/2020

W.O.No. : Nil

Date : 11/03/2019

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44 Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

AMBIENT AIR QUALITY TEST RESULTS

SL.	Location(s)	Date of	2, 0,		NO ₂ (μg/m³)	SO₂ (μg/m³)	
No.	Limit(s)	Sampling	60 (24 Hrs. Av.)	100 (24 Hrs. Av.)	80 (24 Hrs. Av.)	80 (24 Hrs. Av.)	
1.	In-front of Guest House	01.01.2020	26.4	35.7	BDL	BDL	
2.	Near Crusher Area	01.01.2020	32.7	62.5	6.2	BDL	
3.	In- Front of Compressor House (Cement Mill)	02.01.2020	27.6	60.2	6.8	BDL	
4.	Near Mines	02.01.2020	30.4	71.8	9.2	BDL	

Analysis Protocol: IS 5182

BDL: Below Detectable Level



Checked By: Mr. Pankaj Baroi, ENVIROCON

NOTE: 1. Results reported are valid at the time of and under the prevailing conditions of measurement.

2. Results refer only to the particular parameters tested.



Digboi Stores Building, New Market Digboi, Assam – 786 171 Ph: 03751-264414, 9435008657, 8876028672

E-mail: envirocon@rediffmail.com Website: www.envirocon.net.in



Report No.: ENV/HCCL/SE/JAN/19-20/01

Date : 10/01/2020

W. O. No. : Nil

Date : 11/03/2019

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44 Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

STACK EMISSION TEST RESULTS

Sl. No.	Parameter(s)	Result(s)	Unit(s)	Limit(s	
Cl No	Donomotou(a)	Desultin	Huller	I Imalife	
10	Analysi	s Results of Flue Gas			
09	Type of Fuel Used	NA*			
08	Flow Rate (Nm³/hr)		16799		
07	Exit Velocity of Gas (m/sec)	6.2			
06	Flue Gas Temperature (°C)	38			
05	Stack Diameter (Meter)	1.0			
04	Stack Attached To	B. F. of Crusher			
03	Material of Construction	M. S.			
02	Date of Sampling		01.01.2020		
01	Stack Emission Test Ref. No.	HCCL/SE/19-20/01-01			

*NA: Not Applicable



Checked By: Mr. Pankaj Baroi, ENVIROCON

NOTE: 1. Results reported are valid at the time of and under the prevailing conditions of measurement.

2. Results refer only to the particular parameters tested.



Digboi Stores Building, New Market Digboi, Assam – 786 171 Ph: 03761-264414, 9435008657, 8876028672 E-mail: envirocon@rediffmail.com Website: www.envirocon.net.in



Report No.: ENV/HCCL/SE/JAN/19-20/02

Date : 10/01/2020

W. O. No. : Nil

Date : 11/03/2019

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44 Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

STACK EMISSION TEST RESULTS

01	Stack Emission Test Ref. No.	HCC	HCCL/SE/19-20/01-02			
02	Date of Sampling		01.01.2020			
03	Material of Construction		M. S.			
04	Stack Attached To		R.A.B.H.			
05	Stack Diameter (Meter)	3.0				
06	Flue Gas Temperature (°C)	190				
07	Exit Velocity of Gas (m/sec)	22.4				
08	Flow Rate (Nm³/hr)		366923			
09	Type of Fuel Used		NA*			
10	Analysis	s Results of Flue Gas				
Sl. No.	Parameter(s)	Result(s)	Unit(s)	Limit(s)		
i.	Particulate Matter (as PM)	25.8	mg/Nm³	30		
ii.	Sulphur Dioxide (as SO ₂)	674.3	mg/Nm³	1000		
iii.	Oxides of Nitrogen (as NO _x)	399.9	mg/Nm³	800		

*NA: Not Applicable



Checked By: Mr. Pankaj Baroi, ENVIROCON

NOTE: 1. Results reported are valid at the time of and under the prevailing conditions of measurement.

2. Results refer only to the particular parameters tested.



Digboi Stores Building, New Market Digboi, Assam – 786 171 Ph: 03761-264414, 9435008657, 8876028672 E-mail: envirocon@rediffmail.com Website: www.envirocon.net.in



Report No.: ENV/HCCL/SE/JAN/19-20/03

Date : 10/01/2020

W. O. No. : Nil

Date : 11/03/2019

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44 Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

STACK EMISSION TEST RESULTS

01	Stack Emission Test Ref. No.	нс	HCCL/SE/19-20/01-03			
02	Date of Sampling		01.01.2020			
03	Material of Construction		M. S.			
04	Stack Attached To		Coal Mill			
05	Stack Diameter (Meter)		1.2			
06	Flue Gas Temperature (°C)		66			
07	Exit Velocity of Gas (m/sec)		17.4			
08	Flow Rate (Nm ³ /hr)		62284			
09	Type of Fuel Used		Coal			
10	Analysi	s Results of Flue Gas				
Sl. No.	Parameter(s)	Result(s)	Unit(s)	Limit(s)		
i,	PM- Particulate Matter	24.6	mg/Nm³	30		
íl.	Sulphur Dioxide (as SO ₂)	748.42	mg/Nm³	1000		
iii.	Oxides of Nitrogen (as NO _x)	433.39	mg/Nm³	800		



Checked By: Mr. Pankaj Baroi, ENVIROCON

E: 1. Results reported are valid at the time of and under the prevailing conditions of measurement.

2. Results refer only to the particular parameters tested



PCB, Assam & MSPCB, Meghalaya

Digboi Stores Building, New Market Digboi, Assam - 786 171 Ph: 03761-264414, 9435008657, 8876028672 E-mail: envirocon@rediffmail.com

Website: www.envirocon.net.in

Certified Certified

Report No.: ENV/HCCL/SE/JAN/19-20/04

Date : 10/01/2020 W. O. No. : Nil

: 11/03/2019

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44 Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

STACK EMISSION TEST RESULTS

01	Stack Emission Test Ref. No.	HCCL/SE/19-20/01-04					
02	Date of Sampling	02.01.2020					
03	Material of Construction	M. S.					
04	Stack Attached To	Cooler E.S.P.					
05	Stack Diameter (Meter)	2.8					
06	Flue Gas Temperature (°C)	226					
07	Exit Velocity of Gas (m/sec)	17.2					
08	Flow Rate (Nm³/hr)	227724					
09	Type of Fuel Used	NA*					
10	Analysi	Analysis Results of Flue Gas					
Sì. No.	Parameter(s)	Result(s)	Unit(s)	Limit(s)			
i.	PM- Particulate Matter	23.6	mg/Nm³	30			

*NA: Not Applicable



Checked By: Mr. Pankaj Baroi, ENVIROCON

- 1. Results reported are valid at the time of and under the prevailing conditions of measurement.
- 2. Results refer only to the particular parameters tested.
- 3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, Digboi Stores Building, New Market, Digboi 786171, Assam.



Digboi Stores Building, New Market Digboi, Assam – 786 171 Ph: 03751-264414, 9435008657, 8876028672 E-mail: envirocon@rediffmail.com Website: www.envirocon.net.in



Report No.: ENV/HCCL/SE/JAN/19-20/05

W. O. No. : Nil

Date : 10/01/2020

Date : 11/03/2019

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44 Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

STACK EMISSION TEST RESULTS

SI. No.	Parameter(s)	Result(s)	Unit(s)	Limit(s)		
10	Analysi	s Results of Flue Gas				
09	Type of Fuel Used		NA*			
08	Flow Rate (Nm³/hr)		54570			
07	Exit Velocity of Gas (m/sec)	15.2				
06	Flue Gas Temperature (°C)	65				
05	Stack Diameter (Meter)	1.2				
04	Stack Attached To	Cement Mill				
03	Material of Construction	M. S.				
02	Date of Sampling	02.01.2020				
01	Stack Emission Test Ref. No.	HCCL/SE/19-20/01-05				

*NA: Not Applicable



Checked By: Mr. Pankaj Baroi, ENVIROCON

NOTE: 1. Results reported are valid at the time of and under the prevailing conditions of measurement.

2. Results refer only to the particular parameters tested.



Digboi Stores Building, New Market Digboi, Assam – 786 171 Ph: 03751-264414, 9435008657, 8876028672 E-mail: envirocon@rediffmail.com

E-mail: envirocon@rediffmail.co: Website: www.envirocon.net.in



Report No.: ENV/HCCL/SE/JAN/19-20/06

Date : 10/01/2020

W.O. No. : Nil

Date : 11/03/2019

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44 Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

STACK EMISSION TEST RESULTS

SI. No.	Parameter(s)	Result(s)	Unit(s)	Limit(s)	
10	Analysi	s Results of Flue Gas		10 - 1 - 1	
09	Type of Fuel Used	NA*			
08	Flow Rate (Nm³/hr)	24146			
07	Exit Velocity of Gas (m/sec)	13.7			
06	Flue Gas Temperature (°C)	33			
05	Stack Diameter (Meter)	0.8			
04	Stack Attached To	Packing House			
03	Material of Construction	M. S.			
02	Date of Sampling	02.01.2020			
01	Stack Emission Test Ref. No.	HCCL/SE/19-20/01-06			

*NA: Not Applicable



Checked By: Mr. Pankaj Baroi, ENVIROCON

NOTE: 1. Results reported are valid at the time of and under the prevailing conditions of measurement.

2. Results refer only to the particular parameters tested.



Digboi Stores Building, New Market Digboi, Assam - 786 171 Ph: 03751-264414, 9435008657, 8876028672

E-mail: envirocon@rediffmail.com Website: www.envirocon.net.in



Report No.: ENV/HCCL/STP/JAN/19-20/01

Date : 10/01/2020

W. O. No. : Nil

Date : 26/09/2019

M/s HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44 Sub Division: Khliehriat, Dist.: Jaintia Hills

Meghalaya

WASTE WATER ANALYSIS RESULTS

Sample Type : STP Treated Water

Sample Source : STP Outlet

Collected By : Jointly by Envirocon & Client

Collected On : 02.01.2020

SI. No.	Parameter(s)	Unit(s)	Result(s)	Desirable Limit (CPCB Norms)
1.	pH		6.6	5.5 - 9.0
2.	Temperature	°C	18.2	shall not exceed 5°C above the receiving water temperature
3.	Total Suspended Solids	mg/l	12.8	100
4.	Biochemical Oxygen Demand (3 Days @27°C)	mg/l	19	30
5.	Chemical Oxygen Demand	mg/l	62	250
6.	Oil & Grease	mg/l	<0.1	10
7.	Total Residual Chlorine	mg/l	<0.01	1.0
8.	Ammonical Nitrogen (as N)	mg/l	6.1	50
9.	Total Kjeldahl Nitrogen (as NH ₃)	mg/l	17.8	100
10.	Free Ammonia (as NH ₃)	mg/l	<0.01	5.0

Analysis Protocol: IS 3025

ND: Not Detected



Checked By: Mr. Pankaj Baroi, ENVIROCON

NOTE: 1. Results reported are valid at the time of and under the prevailing conditions of measurement.

2. Results refer only to the particular parameters tested.