



HCCL/MSPCB/21-22/08

Date: 18/02/22

To,

The Member Secretary,
Meghalaya State Pollution Control Board
ARDEN Lumpyngngad
Shillong (Meghalaya) -793014

Subject: Reports on Ambient Air Quality test, Stack Emission test, Waste Water Analysis (STP) & Noise Level Measurement Test for the month of January 2022

Dear Sir,

Please find enclosed herewith to this letter the reports for the month of January 2022 for the following test results:-

<u>S1 No.</u>	Test Results	<u>Purpose</u>
1	Ambient Air Quality	-
2	Stack Emission	R.A.B.H
3	Stack Emission	Coal Mill
4	Stack Emission	Cooler E.S.P
5	Waste Water Analysis Result (Treated)	STP Water Analysis
6	Noise Level Measurement Test	

Thanking you,

For Hills Cement Company Ltd

HILLS CEMENT COMPANY LTD.

Authorised Signatory

Copy To: - The Joint Director (S), Ministry of Environment, Forest & Climate Change NE Regional Office, Lumbatngen, Shillong-793021 for information



Website: www.tajcement.com CIN: U26942ML2003PLC007295

HCCL/MSPCB/21-22/08

Date: 18/02/22

To,
The Member Secretary,
Meghalaya State Pollution Control Board
ARDEN Lumpyngngad
Shillong (Meghalaya) -793014

Subject: Reports on Ambient Air Quality test, Stack Emission test, Waste Water Analysis (STP) & Noise Level Measurement Test for the month of January 2022

Dear Sir,

Please find enclosed herewith to this letter the reports for the month of January 2022 for the following test results:-

<u>S1 No.</u>	Test Results	Purpose
1	Ambient Air Quality	
2	Stack Emission	R.A.B.H
3	Stack Emission	Coal Mill
4	Stack Emission	Cooler E.S.P
5 Waste Water Analysis Res (Treated)		STP Water Analysis
6	Noise Level Measurement Test	

Thanking you,

For Hills Cement Company Ltd

HILLS CEMENT COMPANY LTD.

Authorised Signatory

Copy To: - The Joint Director (S), Ministry of Environment, Forest & Climate Change NF Regional Office, Lumbaingen, Shillong-793021 for information

HILLS CEMENT COMPANY LIMITED

ISO 9001:2015 Certified ISO 45001:2018 Certified

Report No.: ENV/HCCL/21-22/AA-01/01

Date : 08/02/2022

Order No.: HCCL/HO/ENV/21-22/01

Date : 08/04/2021

Report Issued To: HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44, Sub Division: Khliehriat, Dist.: Jaintia Hills, Meghalaya

AMBIENT AIR QUALITY TEST RESULTS

St. No.	LOCATION(S)↓	Date of Sampling	PM 2.5 (μg/m³)	PM 10 (μg/m³)	SO ₂ (μg/m ³)	NO ₂ (μg/m³)
	LIMIT(S) →		60	100	80	80
01	In-front of Guest House	24.01.2022	23.2	44.8	<5.0	<6.0
02	Near Crusher Area	25.01.2022	27.9	51.6	5.3	7.3
03	In-Front of Compressor House (Cement Mill)	24.01.2022	24.6	48.3	6.7	7.2
04	Near Mines	25.01.2022	30.3	52.6	<5.0	<6.0

Analysis Protocol: IS 5182



Checked By: Mr. Pankaj Baroi, ENVIROCON

NOTE:

- 1. Results reported are valid at the time of and under the prevailing conditions of measurement.
- 2. Results refer only to the particular parameters tested.
- 3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, I.O.C.L (AOD) New Market, Digboi 786171, Assam.

ISO 9001:2015 Certified ISO 45001:2018 Certified

Report No.: ENV/HCCL/21-22/N-01/01

Date : 08

:08/02/2022

Order No.: HCCL/HO/ENV/21-22/01


Date : 08/04/2021

Report Issued To: HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44, Sub Division: Khliehriat, Dist.: Jaintia Hills, Meghalaya

NOISE LEVEL MEASUREMENT RESULTS

	Location(s)	Date	Day Time		Night Time	
Sl. No.		Of Measurement	L _{eq} (dB-A)	Limit (dB-A)	L _{eq} (dB-A)	Limit (dB-A)
1	In-front of Guest House	24.01.2022	49.6	75	41.9	70
2	Near Crusher Area	24.01.2022	72.8	75	63.5	70
3	In- Front of Compressor House (Cement Mill)	25.01.2022	73.1	75	65.7	70
4	Near Mines	25.01.2022	44.9	75	36.8	70



Checked By: Mr. Pankaj Baroi, ENVIROCON

NOTE: 1. Results reported are valid at the time of and under the prevailing conditions of measurement.

2. Results refer only to the particular parameters tested.

3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, I.O.C.L (AOD) New Market, Digboi - 786171, Assam.

ISO 9001:2015 Certified ISO 45001:2018 Certified

Report No.: ENV/HCCL/21-22/SE-01/01

Date : 08/02/2022

Order No.: HCCL/HO/ENV/21-22/01

Date : 08/04/2021

Report Issued To: HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44, Sub Division: Khliehriat, Dist.: Jaintia Hills, Meghalaya

STACK EMISSION TEST RESULTS

01	Test Ref. No.	I	HCCL/21-22/SE-01/01			
02	Date of Sampling		24.01.2022			
03	Material of Construction		M. S.			
04	Stack Attached To		R.A.B.H.			
05	Stack Diameter (Meter)		3.0			
06	Flue Gas Temperature (°C)		174			
07	Exit Velocity of Gas (m/sec)		18.3			
08	Flow Rate (Nm³/hr)		310492			
09	Type of Fuel Used		NA*			
	Analy	sis Results of Flue Gas				
Sl. No.	Parameter(s)	Result(s)	Unit(s)	Limit(s)		
i.	Particulate Matter	22	22 mg/Nm ³ 30			
ii.	Sulphur Dioxide (as SO ₂)	626	626 mg/Nm ³ 1000			
iii.	Oxides of Nitrogen (as NO _x)	384	384 mg/Nm³ 800			

*NA: Not Applicable



Checked By: Mr. Pankaj Baroi, ENVIROCON

NOTE: 1. Results reported are valid at the time of and under the prevailing conditions of measurement.

2. Results refer only to the particular parameters tested.

3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, I.O.C.L (AOD) New Market, Digboi - 786171, Assam.

ISO 9001:2015 Certified ISO 45001:2018 Certified

Report No.: ENV/HCCL/21-22/SE-01/03

Date : 08/02/2022

Order No.: HCCL/HO/ENV/21-22/01

Date : 08/04/2021

Report Issued To: HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44, Sub Division: Khliehriat, Dist.: Jaintia Hills, Meghalaya

STACK EMISSION TEST RESULTS

01	Test Ref. No.	HCCL/21-22/SE-01/03			
02	Date of Sampling	25.01.2022			
03	Material of Construction	M. S.			
04	Stack Attached To	Coal Mill			
05	Stack Diameter (Meter)	1.2			
06	Flue Gas Temperature (°C)	53			
07	Exit Velocity of Gas (m/sec)	11.7			
08	Flow Rate (Nm³/hr)	43551			
09	Type of Fuel Used	Coal			
	Analysis Resul	ts of Flue Gas			
Sl. No.	Parameter(s)	Result(s)	Unit(s)	Limit(s)	
1.	Particulate Matter	. 19 mg/Nm³ 30			
ii.	Sulphur Dioxide (as SO ₂)	499 mg/Nm ³ 1000			
iii.	Oxides of Nitrogen (as NO _x)	306	mg/Nm³	800	



Checked By: Mr. Pankaj Baroi, ENVIROCON

NOTE: 1. Results reported are valid at the time of and under the prevailing conditions of measurement.

2. Results refer only to the particular parameters tested.

3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, I.O.C.L (AOD) New Market, Digboi - 786171, Assam.

ISO 9001:2015 Certified ISO 45001:2018 Certified

Report No.: ENV/HCCL/21-22/SE-01/02

Date : 08/02/2022

Order No.: HCCL/HO/ENV/21-22/01

Date : 08/04/2021

Report Issued To: HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44, Sub Division: Khliehriat, Dist.: Jaintia Hills, Meghalaya

STACK EMISSION TEST RESULTS

01	Test Ref. No.	F	HCCL/21-22/SE-01/02			
02	Date of Sampling		25.01.2022			
03	Material of Construction		M. S.			
04	Stack Attached To		Cooler E.S.P.			
05	Stack Diameter (Meter)		2.8			
06	Flue Gas Temperature (°C)		217			
07	Exit Velocity of Gas (m/sec)		7.9			
08	Flow Rate (Nm³/hr)		106515			
09	Type of Fuel Used		NA*			
	Analy	sis Results of Flue Gas				
Sl. No.	Parameter(s)	Result(s)	Unit(s)	Limit(s)		
ł.	Particulate Matter	24	24 mg/Nm³			
ii.	Sulphur Dioxide (as SO ₂)	BDL#	BDL# mg/Nm³ 100			
III.	Oxides of Nitrogen (as NO _x)	BDL#	BDL# mg/Nm³ 800			

*NA: Not Applicable

#BDL: Below Detectable Limit



Checked By: Mr. Pankaj Baroi, ENVIROCON

NOTE:

- 1. Results reported are valid at the time of and under the prevailing conditions of measurement.
- 2. Results refer only to the particular parameters tested.
- 3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, I.O.C.L (AOD) New Market, Digboi 786171, Assam.

Envirocon Building, I.O.C.L (AOD) New Market P.O.: Digboi, Dist.: Tinsukia, Assam – 786 171 Ph: 03751-264414, 9435008657, 8876028672

E-mail: envirocon@rediffmail.com

ISO 9001:2015 Certified ISO 45001:2018 Certified

Report No.: ENV/HCCL/21-22/WW-01/01

Date : 08/02/2022

Order No.: HCCL/HO/ENV/21-22/01

Date : 08/04/2021

Report Issued To: HILLS CEMENT COMPANY LIMITED

Village: Mynkree, 116 KM Stone, NH-44, Sub Division: Khliehriat, Dist.: Jaintia Hills, Meghalaya

WASTE WATER ANALYSIS RESULTS

Sample Ref. No.

: HCCL/21-22/WW-2501/01

Sample Type/Source

: Waste Water (Treated)/STP Outlet

Sample Collected By

: Representative of ENVIROCON

Sample Collected On Sample Received On

: 25.01.2022 : 29.01.2022

Analysis Protocol

: IS 3025

Sl. No.	Parameter(s)	Unit(s)	Result(s)	Limit (As Per CPCB Standards)
1.	рН		6.73	5.5 - 9.0
2.	Temperature	0C	23.2	shall not exceed 5°C above the receiving water temperature
3.	Total Suspended Solids	mg/l	14	100
4.	Biochemical Oxygen Demand	mg/l	21	30
5.	Chemical Oxygen Demand	mg/l	95	250
6.	Oil & Grease	mg/l	<4.0	10
7.	Total Residual Chlorine	mg/l	<0.01	1.0
8.	Ammonical Nitrogen (as N)	mg/l	2.6	50
9.	Total Kjeldahl Nitrogen (as NH ₃)	mg/l	9.4	100
10.	Free Ammonia (as NH ₃)	mg/l	<0.01	5.0



Checked By: Mr. Pankaj Baroi, ENVIROCON

NOTE:

- 1. Results reported are valid at the time of and under the prevailing conditions of measurement.
- 2. Results refer only to the particular parameters tested.
- 3. This test report shall not be reproduced except in full, without the written permission of ENVIROCON, I.O.C.L (AOD) New Market, Digboi 786171, Assam.